

TSSPDCL - LMRC / Corporate office

Date: 07.12.16

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	Madgula 2	33KV	Jadcherla	01.15	06.00	04.45	O/L	LV fuse problem at 33KV Madgula SS	Madgula 2	No
2		Wanaparthi	Pebbair	33KV	Wanaparthi	11.43	14.45	03.02	E/L	Pin insulater damaged, Jumper cut and Replace at 220KV Bick Side	Pebbair	No

TSSPDCL - LMRC / Corporate office

Date: 07.12.16

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mandollagudem	Prathista Industrial	11KV	Nalgonda	13:00	16:10	3:10	E/L	11KV Insulator failed at SS-1	No
2		Yellanki	Yellanki	11KV	Nalgonda	08.20	10.50	02.30	E/L	11KV Line cut at Oppsit Sub station	No
3		Marriguda	Kondur	11KV	Devarakonda	04.00	07.00	03.00	E/L	11kv Jumper cut	No
4		Chamapur	Singaram	11KV	Bhongir	13.30	17.30	04.00	E/L	11KV Line snapped near Chandepally X Road	No
1	MDK	Siripura	Siripura	11KV	Medak	1:00	4:00	3:00		Jumper cut	No
2		Cheryal	Kalivemula	11KV	Sangareddy	11.00	12.10	01.10		Insulator failed	No

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	203									
5	RR(N)	75	396									
6	RR(E)	41	337									
7	Hyd	163	965									
	<b>Total</b>	<b>466</b>	<b>2801</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	2		2		2				
2	NLG	120	738		4		4		4			
3	MDK	81	695		2		2		2			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	<b>Total</b>	<b>336</b>	<b>2789</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>802</b>	<b>5590</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	