

## TSSPDCL - LMRC / Corporate office

Date: 14.12.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kadthal	Industrial	11kv	Jadcherla	14.30	17.40	03.10		11kv Jumper cut near Kadthal	-
2		Balanagar	Amithcottonmill	11kv	Jadcherla	08.50	15.30	06.40		11kv wire cut near Rangareddy guda	-
3		Shadnagar	Balaji	11kv	Jadcherla	13.25	15.40	02.15		11kv Insulator fail near Shadnagar	-
1	NLG	Kasarabadha	Imampeta	11kv	Suryapet	10.00	12.25	02.25	E/L	11Kv Jumper cut SS-4	-
2		Thimmanaguda	Thelakantigudem	11kv	Nalgonda	08.00	10.10	02.10	E/L	Tree fallen on line	-
3		B.Vellemla	Auravani	11kv	Nalgonda	06.00	08.30	02.30	E/L	11 KV Line milting	-
1	MDK	Shalipet	Chennaipally	11kv	Medak	10.05	15.00	04.55		B/D due to Conductor snapped	-
2		Narsapur	Avancha	11kv		11.00	15.15	04.15		B/D due to Jumper cut	-
3		Hathnoora	Nawabpet	11kv		05.00	08.00	03.00		B/D due to 11 KV Insulater failed	-
4		SRD Town-II	Kalabgoor	11kv	Sangareddy	11.45	14.00	02.15		BD for jumper cut at Irigipally vlg	-
5		Cherial	Indrakaran	11kv		11.00	12.30	01.30		BD for due to rain	-
6		Cherial	Kandi	11kv		11.05	14.05	03.00		BD for transformer repair at Mamidiapally vlg	-
7		Cherial	Kandi	11kv		09.05	09.35	00.30		BD for 11kv breaker relay problem	-

## TSSPDCL - LMRC / Corporate office

Date: 14.12.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Champapet	Jillelguda	11kv	CPT	08.30	10.25	01.55	EL/ BD	Insulators failed and replaced work at Manda mallamma garden	-
2		IGS SS	Indirashivashakti	11kv	RJNR	23.00	00.50	01.50	B/D	Tree branches fallen on 11KV line at Vishaka Plastic	-
3		Kattedan-II	Jalpally	11kv	RJNR	23.00	Still		B/D	11kv Cable Problem	-
4		MD Pally	Bandlaguda	11kv	RJNR	23.30	01.30	02.00	B/D	Kite sticks fallen on 11KV line at Jahangirabad	-
5		MD Pally	IDA MD Pally	11kv	RJNR	23.30	01.45	02.15	B/D	Kite sticks fallen on 11KV line at Pallecheruvu	-
6		NPA	Shivarampally	11kv	RJNR	23.06	00.40	01.34	B/D	11KV Jumper cut at Nethaji youth Club Shivarampally	-
7		NPA	Babulreddy nagar	11kv	RJNR	23.15	01.20	02.05	B/D	Kite stick fallen on 11kv line Leelavathi Company Babulreddynagar	-
8		NPA	Shastripuram	11kv	RJNR	23.18	00.48	01.30	B/D	11KV Line Twisted at Baba Kanta	-
9		NPA	Shastripuram	11kv	RJNR	12.33	13.50	01.17	B/D	Kite sticks fallen on 11KV line at Sattar Masjid	-
10		NPA	Babulreddy nagar	11kv	RJNR	12.19	13.25	01.06	B/D	Kite stick Touching To Channel at markandey nagar	-
11		Gaganpahad	Jaibhavani	11kv	RJNR	08.35	09.28	00.53	B/D	No Visible fault	-
12		Gaganpahad	NPA(GPHD)	11kv	RJNR	12.29	13.27	00.58	B/D	11kv Line Snapped at Church Street	-
13		Gandham Guda	Suncity	11kv	RJNR	09.00	10.23	01.23	B/D	No Visible fault	-
14		Gandham Guda	Suncity	11kv	RJNR	12.10	13.19	01.09	B/D	No Visible fault	-
15		APPA	Aziznagar	11kv	RJNR	10.05	12.05	02.00	B/D	11kv Insulator Failed at Saz college	-
16		Ibrahimbagh	Military-II	11kv	RJNR	12.32	13.43	01.11	B/D	11kv insulator Failed at ARMY School	-
17		CBIT	CBIT	11kv	RJNR	23.04	01.50	02.46	B/D	Tree branches fallen on 11KV line at Shantinagar	-
18		Kokapet	Babukhan	11kv	RJNR	08.42	10.33	01.51	B/D	No Visible fault	-
19		Puppalaguda	Alkapuri	11kv	RJNR	15.02	15.44	00.42	B/D	11kv Cable Kit Failed at Alkapur township	-

## TSSPDCL - LMRC / Corporate office

Date: 14.12.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Chandanagar	Mythri Nagar	11kv	GCB	08.55	11.05	02.10	BD	11kv Pin Insulator at Vikas Apartments, Mythri Nagar	-
2		Gachibowli	Kalajyothi	11kv	GCB	00.00	02.00	02.00	BD	11kv AB Cable Touch to 11kv Line Near SS	-
3		Borabanda	Padmavathi Nagar	11kv	GCB	08.50	10.15	01.25	BD	11kv AB Cable Failed at Rana Pratap Nagar	-
4		ESCI	Divya Sree	11kv	GCB	02.20	04.00	01.40	BD	11kv UG Cable Damage at Biocity, Divya Sree	-
5		Nanakramguda	Gowlidoddi	11kv	GCB	09.05	10.34	01.29	BD	100kv T/F Brass Patti Cut To Touch On The Iron Pole at Woder Basti	-
6		Nanakramguda	Gowlidoddi	11kv	GCB	12.58	14.10	01.12	BD	11kv Pin Insulator at Journalist Colony	-
7		Jeedimetla SS I	Raghava	11kv	KKP	08.30	10.20	01.50	BD	11kv AB Cable failure near KLJ Plastic at Phase I & Out going jumper cut at SS Yard	-
8		Jeedimetla SS I	Phase V, Balaji, Subh ashnagar	11kv	KKP	10.55	13.25	02.30	BD	Lorry dash the 5 No's poles at Phase-I, Pipe line road	-
1	RR E	Nacharam	Chandamama	11kv	HBG	07.28	08.51	01.23		11KV Line cut near Road No.09 at IDA Nacharam	-
1	HYD S	Aliabad	Masrath Function Hall	11kv	III	00.18	02.55	02.37	EL	I/C Cable fault	Arranged B/F on 11KV Boys Town feeder
2		Attapur	Puranapool	11kv	III	01.10	02.35	01.25	EL	No Visible Fault	----
3		Malakpet	Dabeerpura	11kv	VIII	02.10	04.07	01.57	EL	No Visible Fault	Arranged B/F on 11KV Yashoda Hospital fdr
4		Kandikal Gate	Rakshapuram	11kv	III	08.27	10.45	02.18	EL,OL	Tree branches fallen on lines at Rakshapuram	----
5		Panjasha	Sulthan Shahi	11kv	III	15.22	16.50	01.28	EL,OL	RMU fault at Volga Hotel	----
6	Hyd C	S.D.Hospital	Humayun Nagar	11kv	VII	08.21	09.35	01.14	EL	Pin Insulator flash over at K.F.C.	----

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Bhoothpur	Kodur	33kv	Mahabubnagar	00.20	08.35	08.15	E/L	No Visuable Fault was Found	Kodur	Load Divertted to 33KV Koukuntla Feeder
2		Maddur	Damargidda	33kv	Mahabubnagar	15.05	18.50	03.45	E/L	Insulator Damaged at Kyathanpally	Damargidda	NO
3		Kosgi	Surayapally	33kv	Mahabubnagar	14.14	17.20	03.06	E/L	Insulator Damaged at Darga	Surayapally	NO
4		Amangal	Madgula 2	33kv	Jadcherla	00.40	11.40	11.00	E/L	Insulator Damaged at Amangal Town	Madgula 2	NO
5		Sri Rangapur	Kondurg	33kv	Jadcherla	09.10	11.52	02.42	E/L	No Visuable Fault	Kondurg	NO
6		Sri Rangapur	Kondurg	33kv	Jadcherla	14.00	16.53	02.53	E/L	No Visuable Fault and Y Phase CT Faile at 33 KV Veerannapet	Kondurg	NO
7		Balanagar	Kollur	33kv	Jadcherla	09.20	10.05	00.45	E/L	Due to Line Problem	Kollur	NO
8		Shadnagar	Salasar	33kv	Jadcherla	14.50	16.20	01.30	E/L	No Visuable Fault	Salasar	Alternate Supply Arranged from 33KV Rakonda at 21:40 Hrs
1	NLG	Kolanupaka	Alair	33kv	Bhongir	11.45	13.20	01.35	E/L	33KV Jumper Snapped near Alair Functional	Alair	Motakondur
2		Guntipally	Padmatipally	33kv	Devarakonda	06.30	09.30	03.00	E/L	33Kv Insulator Failed	Padmatipally	NO
1	MDK	Manoharabad	Shivampet	33kv	Toopran	10.15	16.00	05.45		B/D due to 33KV Insulator Failed near Sikindlapur SS	Shivampet	NO
2		Sadashivapet	Munipally	33kv	Sangareddy	01.45	04.55	03.10		B/D due to 33KV Insulator Failed	Munipally	NO
3		Zaheerabad	Jharasangem	33kv	Zaheerabad	02.00	04.00	02.00		B/D due to 33KV Insulator Failed	Jharasangem	NO
4			Mirjapur	33kv		02.25	12.10	09.45		B/D due to Jumper cut	Mirjapur	NO
5			Hadnoor	33kv		02.50	10.20	07.30		B/D due to 33KV Insulator Failed	Hadnoor	NO

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	203		19		19		19			
5	RR(N)	75	396		8		8		8			
6	RR(E)	41	337		1		1		1			
7	Hyd	163	965		6		6		6			
	<b>Total</b>	<b>466</b>	<b>2801</b>	<b>0</b>	<b>34</b>	<b>0</b>	<b>34</b>	<b>0</b>	<b>34</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	8	3	8	3	8	3			
2	NLG	120	738	2	3	2	3	2	3			
3	MDK	81	695	5	7	5	7	5	7			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	<b>Total</b>	<b>336</b>	<b>2789</b>	<b>15</b>	<b>13</b>	<b>15</b>	<b>13</b>	<b>15</b>	<b>13</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>802</b>	<b>5590</b>	<b>15</b>	<b>47</b>	<b>15</b>	<b>47</b>	<b>15</b>	<b>47</b>	<b>0</b>	<b>0</b>	