

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	83	350									
4	RR(S)	40	201		1		1		1			
5	RR(N)	74	396									
6	RR(E)	41	337									
7	Hyd	163	965		1		1		1			
	<b>Total</b>	<b>465</b>	<b>2799</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	1	1	1	1	1	1			
2	NLG	120	738		2		2		2			
3	MDK	81	695	1	1	1	1	1	1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	<b>Total</b>	<b>336</b>	<b>2789</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>801</b>	<b>5588</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 19.10.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Narsaipally	33KV	Wanaparthi	21.55	01.35	03.40	E/L	33KV Jumper cut near Wanaparthi	Narsaipally	-
1	MDK	Kowdipally	CH Ghanpur	33KV	Medak	08.15	12.15	04.00		B/D due to Disk failure.	CH Ghanpur	-

TSSPDCL - LMRC / Corporate office

Date: 19.10.2016

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Eklaapur	Eklaapur	11KV	Mahabubnagar	09.10	12.30	03.20		11KV insulator Damaged near Kanmanoor (vi)	-
1	NLG	Bibigudem	Chivemla Agl	11KV	Suryapet	06.00	09.00	03.00	E/L	11Kv Jumper cut	-
2		Keethavarigudem	Kothagudem	11KV	Huzurnagar	06.00	09.30	03.30	E/L	11 kv line snapped at kothagudem village	-
1	MDK	Moosapet	Nagulapally	11KV	Medak	02.00	10.50	08.50		B/d due to Conductor snapped.	-
1	RR S	Kokapet	Ocean park	11KV	RJNR	05.55	06.58	01.03	B\D	leazard fallen on 11KV line near Lezand	-
1	HYD S	Kanchan Bagh	Kanchan Bagh	11KV	VIII	19.53	21.40	01.47	EL	Breaker fault at SS	Arranged B/f on 11KV Darga OH