

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	52	153									
2	NLG	12	397									
3	MDK	82	350									
4	RR(S)	40	201		4		4		4			
5	RR(N)	74	389	1	10	1	10	1	10			
6	RR(E)	41	331									
7	Hyd	161	964		16		16		16			
	Total	462	2785	1	30	1	30	1	30	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	81	891	1	5	1	5	1	5			
2	NLG	109	738		12		12		12			
3	MDK	81	690	3	3	3	2	3	2			1-11KV Still
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	15	79									
	Total	325	2784	4	20	4	19	4	19	0	0	
	Grand Total	787	5569	5	50	5	49	5	49	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.09.2016

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Eklaspur	33KV	Mahabubnagar	06.30	07.10	00.40	E/L	33KV Pin Insulator failed and Replacement at Vaddeman(V)	Eklaspur,Waddeman	-
1	MDK	Singoor	Muddaipet	33KV	Jogipet	03.15	06.15	03.00		B/D due to Jumper Cut near Peddareddypoet(V)	Muddaipet	-
2		Kowdipally	Amsanpally	33KV	Medak	17.45	20.25	02.40		B/D due to 33KV Conductor snapped	Amsanpally	-
3		Zaheerabad	Allahana	33KV	Zaheerabad	04.00	06.30	02.30		B/D due to Insulator failed	Allahana	-
1	RR N	Medchal	Medchal-II	33KV	Medchal	03.40	06.05	02.25	BD	Tripped on EL & OL Y Phase Indication, BD declared to Ae/Op/Medchal Town for Changing of Disc Insulator near CMR College (Alternate Supply arranged)	Medchal-II	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MUNNANUR	VATARLAPALLY	11KV	Nagarkurnool	00.00	08.00	08.00		11 KV LINE WIRE CUT NEAR VATAVARLAPALLY ROAD	-
2		PEDDUR	PEDDUR	11KV	Nagarkurnool	23.00	10.00	11.00		ABSWITCH PRABULAM BOPPELI ROAD	-
3		MANGANUR	CHEGUNTA	11KV	Nagarkurnool	03.00	10.40	07.40		11 KV LINE CUT TO LT LINE NEAR VILL BC COLNEY	-
4		VADDEMAN	KASARAGADDA	11KV	Nagarkurnool	06.30	11.30	05.00		INSULATOR FAILED NEAR PALLEM ROAD	-
5		YELLORE	YELLORE	11KV	Nagarkurnool	00.30	09.00	08.30		NEAR EDDAMA T/F PRABULAM	-
1	NLG	Puttamgandi	Vaddipatla	11KV	Devarakonda	10.30	14.30	04.00	E/L	11kv insulator failure	-
2		Chepur	Mosangi	11KV	Devarakonda	07.00	10.00	03.00	E/L	11kv jumper cutting	-
3		Chepur	Thertigudem	11KV	Devarakonda	06.00	09.00	03.00	E/L	11kv pin insulator failure	-
4		Gaddipally	Medaram	11KV	Huzurnagar	02.00	06.00	04.00	E/L	11 kv line snapped at Jnaladenna village	-
5		Amararam	Srinivasapuram	11KV	Huzurnagar	03.00	07.00	04.00	E/L	11 kv insulator failed at srinivasapuram village	-
6		Motakondur	Motakondur Indus	11KV	Bhongir	08.00	12.00	04.00	E/L	11KV Line snapped near Company	-
7		Pateigudem	Gundlagudem	11KV	Bhongir	07.00	10.00	03.00	E/L	11KV Insulator failed Raghavapur	-
8		Addagudur	Kotamarthy	11KV	Bhongir	14.00	18.00	04.00	E/L	11KV Line snapped & Insulator failed Kotamrathy	-
9		Chandur	Tummalapally	11KV	Nalgonda	07.00	10.00	03.00	E/L	11KV Insulator failed	-
10		Malkapur	Malkapur	11KV	Nalgonda	07.30	11.30	04.00	E/L	11KV Insulator failed	-
11		Thipparthi	Sarvaram	11KV	Nalgonda	10.00	11.45	01.45	E/L	11KV Insulator failed	-
12		Kattangur	Power loom	11KV	Suryapet	06.00	10.00	04.00	E/L	11KV Insulator failed	-
1	MDK	Nallavally	Nallavally Indl	11KV	Medak	07.15	12.50	05.35		B/D due to 11KV Jumper cut at Medalamma temple	-
2		Narsapur	Reddypally	11KV	Medak	11.00	Still			B/D	-
3		CHERIYAL	KANDI	11KV	Sangareddy	08.10	10.30	02.20		B/D DUE TO 11KV PHASE TO PHASE & TREE FALLEN ON THE LINE AT MAMIDPALY	-
1	RR S	Ibrahimbagh	Osmansagar	11KV	RJNR	06.50	08.55	02.05	B/D	Coconut Tree branches fallen on 11KV Line at Royal function hall	-
2		Puppalaguda	Narsing	11KV	RJNR	06.48	09.33	02.45	B/D	11KV Insulator failed at Balaji Residency	-
3		Katedan II	Ravifoods	11KV	RJNR	01.05	02.10	01.05	B/D	CTPT fault at Sabina foods	-
4		Moinabad	Surangal	11KV	RJNR	08.30	09.30	01.00	B/D	11KV Insulator failed at Surangal	-
1	RR N	Hafeezpet	Adithya Nagar	11KV	Gachibowli	20.37	22.07	01.30	BD	11KV Pin insulator failed at Aditya Nagar	-
2		Jeedimetla-I	Nitco	11KV	KKP	01.20	04.20	03.00	BD	Oblam Company Incoming 11kv jumper Cut at Phase-I,(due to heavy rain)	-
3		Mayurinagar	Ramnaresh nagar	11KV	KKP	06.30	07.44	01.14	BD	HG Fuse insulator Failure near Balaji Apt,Brundavan Colony	-
4		Vijayanagar	Jayanagar	11KV	KKP	06.00	06.50	00.50	BD	Tree Branches fallon the 11kv line Road:4,Vijayanagar	-
5		Madinaguda	Swarnapuri	11KV	KKP	07.05	08.35	01.30	BD	11kv line Disk failure near Sai Baba Temple at HMT Colony	-
6		Nizampet	Bandari Lay-Out	11KV	KKP	00.23	02.36	02.13	BD	11kv line Disk failure near Suman Sai Apt Road:9,Bandari Lay-Out	-
7		Shameerpet	Thumkunta	11KV	Medchal	23.05	01.30	02.35	BD	11KV Pin Insulator Failed at Ring Road Shameerpet	-
8		Devarayamjal	Kottapet	11KV	Medchal	01.30	03.15	01.45	BD	11KV Pin Insulator Failed at Platinum Property,Devarayamjal	-
9		Kompally	NCL	11KV	Medchal	06.30	07.46	01.16	BD	Tree Branch Fallen on the 11KV Line at Balaji Recidency,NCL North	-
10		Kompally	Petbasheerabad	11KV	Medchal	20.40	21.55	01.15	BD	11KV Pin Insulator failed at D-Mart	-
1	HYD N	E.S.I.	Zech Colony	11KV	IV	00.20	03.36	03.16	EL	Disc Insulator flash over at Udyog Nagar Park	----
2		Borabanda	Swaraj Nagar	11KV	IV	06.47	09.00	02.13	EL	DTR fault at Swaraj Nagar	----
3		Nehru Nagar	West Marredpally	11KV	V	19.26	21.18	01.52	EL	Jumper cut at SS	Arranged B/f on 11KV Ramser Café feeder
4		Chikalaguda	Dandu Pentaiah	11KV	V	21.00	23.05	02.05	EL,OL	No Visible Fault	Arranged B/f on 11KV Gandhi Nagar PS feeder
5		Gunrock	Lal Bazar	11KV	VI	05.00	06.10	01.10	EL,OL-Bph	No Visible Fault	----
6		Road No.12	Kanaka Durga Temple	11KV	X	09.10	10.25	01.15	EL	Tree branches fallen on Lines at Reliance Digital	----
7		MLA Colony	Lotus Pound	11KV	X	21.30	22.50	01.20	EL,OL-Bph	Insulator flash over at Komat Reddy Venkat Reddy House	----
8		Road No.2	Shabdalya	11KV	X	21.00	23.15	02.15	OL	Jumper cut at Road No.3	----
1	HYD S	Asmangadh	G.A.Bank Colony	11KV	VIII	07.30	10.30	03.00	EL	Kite Stick touching to Lines at G.A.Bank Colony Park	----
2		Malakpet	Dabeerpura	11KV	VIII	21.35	23.40	02.05	EL	AB Switch at Farhath Qtrs	----
3		Malakpet Gunj	Farhath Hospital	11KV	VIII	22.28	00.28	02.00	EL	DTR fault at Deccan Tower	----
4		Durga Nagar	Saleem Nagar	11KV	VIII	21.20	00.40	03.20	EL	UG Cable fault at Jasamin Hotel	Removed loads of 11KV Super Bazar fdr
5		Kandikalgate	G.M.Chowni	11KV	III	21.05	23.20	02.15	EL,OL	HT/LT Line snapped at Dhanaiah Nagar	----
6		Khiwath	Telephone Exchange	11KV	III	22.54	02.06	03.12	EL,OL	RMU fault at Telephone Exchange	Arranged B/f on 11KV Charminar fdr
1	HYD C	Nizam College	Galaxy	11KV	I	22.17	00.46	02.29	EL	2no Pin Insulator flash over at Rajasheela Wines & AB Switch Insulator fault at Satya Dignostic	----
2		Lake View	Dilkusha	11KV	I	22.20	02.05	03.45	EL	RMU fault at Vista Garad & Big tree fallen on lines at Villa Marry College	----