

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	38	209		1		1		1			
5	RR(N)	77	399	1	3	1	3	1	3			
6	RR(E)	38	347		2		2		2			
7	Hyd	183	982		3		3		3			
	Total	494	2884	1	9	1	9	1	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	106	969		2		2		2			
2	NLG	150	948		3		3		3			
3	MDK	87	828									
4	RR(S)	27	316									
5	RR(N)	8	48									
6	RR(E)	18	80									
	Total	396	3189	0	5	0	5	0	5	0	0	
	Grand Total	890	6073	1	14	1	14	1	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.04.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	Divya Sri NSL-B5	Divya Sri NSL-B5	33KV	Gachibowli	01.25	05.20	03.55		cable-II Damaged in SS		-

TSSPDCL - LMRC / Corporate office

Date: 24.04.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Mallepally	11KV	Jadcherla	10.30	12.30	02.00		11kv wire cut near Ediganipally	-
2		Jadcherla	Alwanpally	11KV	Jadcherla	10.00	13.30	03.30		11kv wire cut near degree collegr back side jadcherla	-
1	NLG	Edloor	Naregudem	11KV	Suryapet	10.00	12.00	02.00	E/L	11Kv Jumper cut	-
2		Chityala	Elikatte	11KV	Nalgonda	07.00	09.00	02.00	E/L	11KV Line Insulator Failed	-
3		Yadagirigutta	Wangapally	11KV	Bhongir	14.40	17.40	03.00	EL	11KV Jumper Snapped Wangapally	-
1	RR S	CBIT	Gandipet	11KV	RJNR	07.45	08.55	01.10		Line petrolled, no visible fault found	-
1	RR N	Bommarajpet	Karkamma	11KV	Medchal	12.50	15.00	02.10	BD	11KV Cable Cut & Replaced at Outer Ring Road	-
2		Mayurinagar	Prashanthnagar	11KV	Kukatpally	06.50	08.00	01.10	BD	11kv line UG Cablefailure at Lakviw Colony	-
3		JDNSS-III	Ramreddy Colony	11KV	Kukatpally	07.55	09.30	01.35	BD	CTBT failure near JK Indistrial at phase-V	-
1	RR E	Furit Market	Phingiri colony	11KV	SRNR	04.49	05.59	01.10		HG Fuse Failed at Phingiri colony	-
2		Moula-Ali	Gayathri Nagar	11KV	Sainikpuri	17.15	18.03	00.48		11Kv jumper fault of Iron Pole at Sadulla Nagar (AE/OP/Moula-Ali)	-
1	HYD S	Chanchalguda	Madannapet	11KV	Asmangadh	07.30	08.49	01.19	OL-Rph	No Visible Fault	Arranged B/F on 11KV SRT Colony feeder
2		Aliyabad	Police Quarters	11KV	Charminar	07.35	08.55	01.20	EL	Jumper cut at Meenakshi Apts	-
3		Falaknuma	Ravindra Naik Nagar	11KV	Charminar	22.10	00.09	01.59	EL	Cable fault at Falaknuma Station Road	Arranged B/F on 11KV G.M Chowni feeder