

TSSPDCL - LMRC / Corporate office

Date: 19.02.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD S	220KV Ch' Gutta	Malakpet Gunj	33KV	Malakpet	01.45	01.50	00.05	EL,OL-Bph	Under Breakdown	220KV Ch' Gutta	Loads transferred onto 132KV Imlibun SS via 33KV Malakpet Gunj feeder

TSSPDCL - LMRC / Corporate office

Date: 19.02.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kaverammamet	Bandamidipally	11KV	Jadcherla	07.00	10.00	03.00		11KV Line Phase to Phase near Bandamidipally	-
1	NLG	Marriguda	Kondur	11KV	Devarakodna	08.45	10.15	01.30	E/L	11kv jumper cut	-
2		Nakrekal	Chandupatla	11KV	Suryapet	13.40	17.30	03.50	E/L	11kv jumper cut	-
3		Chandupatla	Chandupatla	11KV	Bhongir	13.00	15.00	02.00	E/L	11KV Line snapped at Katamaiah Temple	-
1	MDK	Chippalthurthy	Jakkapally	11KV	Medak	02.00	06.00	04.00		B/D due to Jumper cut at jakkapally village	-
2		Salabathpur	Salabathpur	11KV	Medak	08.30	11.00	02.30		B/D due to Jumper cut at Jodibai thanda	-
1	RR N	Mathrusri Nagar	Srila	11KV	Gachibowli	17.45	18.45	01.00	EL	11kv AB Switch Spark Near Community Hall at Srila	-
2		JDMSS-II	Exciel	11KV	Kukatpally	16.30	17.50	01.20	EL	Tree fallon the 11kv line,Jumper Cut at Prince pakage,phase-III	-
3		KPHB	HMT	11KV	Kukatpally	03.57	05.10	01.13	EL	11kv line AB Cable failure at opp:Veejetha Super market,plot:213/A,Addagutta	-
1	HYD N	Erramanzil	Hyd. Central	11KV	Erragadda	01.45	03.38	01.53	EL	Cable fault	Arranged B/F on 11KV Topaz Building feeder
1	HYD S	Gunj	Palton	11KV	Asmangadh	03.45	05.40	01.55	OL-Y&Bph	No Visible Fault	-

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	153									
2	NLG	18	406									
3	MDK	85	383									
4	RR(S)	38	237									
5	RR(N)	77	398		3		3		3			
6	RR(E)	38	347									
7	Hyd	169	966	1	2	1	2	1	2			
	<b>Total</b>	<b>473</b>	<b>2890</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	104	894		1		1		1			
2	NLG	150	728		3		3		3			
3	MDK	94	826		2		2		2			
4	RR(S)	31	289									
5	RR(N)	8	49									
6	RR(E)	18	79									
	<b>Total</b>	<b>405</b>	<b>2865</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>878</b>	<b>5755</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>1</b>	<b>11</b>	<b>0</b>	<b>0</b>	