

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407	1	6	1	6	1	6			
6	RR(E)	38	360		1		1		1			
7	Hyd	186	1014		1		1		1			
	Total	504	2929	1	8	1	8	1	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969	1	1	1	1	1	1			
2	NLG	150	948		8		8		8			
3	MDK	87	828	2	5	2	5	2	5			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	Total	404	3220	3	14	3	14	3	14	0	0	
	Grand Total	908	6149	4	22	4	22	4	22	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.07.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gokulnagar	Nandigam	11kv	Mahabubnagar	07.00	09.00	02.00		11KV Insulator Damage at Thimmareddypally (Vi)	-
1	NLG	Nagaram	Wardamanu kota	11kv	Suryapet	14:00	15:48	1:48	E/L	11KV Conductor snapped	-
2		Kalmalchervu	Kalmalchervu	11kv	Huzurnagar	9:30	12:00	2:30	E/L	11Kv jumper cut near Kalmalchervu village	-
3		Dirsincherla	Narasayagudem	11kv	Huzurnagar	12:20	15:30	3:10	E/L	11Kv jumper cut near Narasayagudem village	-
4		Bheelyanaik thand	Pathathanda	11kv	Huzurnagar	11:15	14:30	3:15	E/L	11Kv Conductor snapped near Pathathanda village	-
5		Aregudem	Aregudem	11kv	Nalgonda	6:30	8:00	1:30	E/L	11KV Conductor snapped	-
6		Kopple	Bollaram	11kv	Devarakonda	13:30	16:20	2:50	E/L	11KV Conductor snapped	-
7		Gurraladandi	Raiphad	11kv	Bhongir	0:00	4:00	4:00	E/L	11KV Jumper cut at Raiphad	-
8		Chamapur	Singaram	11kv	Bhongir	8:20	11:00	2:40	E/L	11KV Insulator failed at ss-1 Singaram Village	-
1	MDK	Toopran	Islampur	11kv	Toopran	12.30	13.20	00.50		B/D Due tree Branches fallen on line	-
2		Ramayampet	Ramayampet	11kv	Toopran	12.40	14.45	02.05		B/D Due tree Branches fallen on line	-
3		Shivampet	Shivampet	11kv	Toopran	15.00	17.00	02.00		B/D Due to Jumper Cut	-
4		Shivampet	Gangaipally	11kv	Toopran	15.00	17.00	02.00		B/D Due to Jumper Cut	-
5		Shivampet	Donthi	11kv	Toopran	15.00	17.00	02.00		B/D Due to Insulator failure	-
1	RR N	Nizampet	Bhavyas	11kv	Kukatpally	07.45	08.40	00.55	BD	HT/LT LT line cut near Eshwar villas road at Nizampet	-
2		Gowdavelly	Basaragadi	11kv	Medchal	00.30	02.30	02.00	BD	100 KVA DTR Bras patti cut at MLR Collage Basaragadi	-
3		HMT	Gandhi nagar	11kv	Medchal	10.10	11.50	01.40	BD	11KV Conductor Snapped at Sha Cinemas, Ganesh Nagar	-
4		Ravalkole	Ravalkole	11kv	Medchal	10.20	12.20	02.00	BD	11KV Conductor Snapped at cheruvukatta, Ravalkole	-
5		Thurkapally	Yadaram	11kv	Medchal	12.30	15.00	02.30	BD	11KV Pin Insulator failed at Yadaram Cheruvu	-
6		Kandlakoya	Saigeetha Asramam	11kv	Medchal	13.00	14.30	01.30	BD	11KV Jumper cut at Chaithanya school	-
1	RR E	Moula-Ali	Mirzalguda	11kv	Sainikpuri	12.10	12.55	00.45		Tree branches fallen on 11Kv line at Opposite Petrol Bunk ZTS (LM Ashok)	-
1	HYD C	Asif Nagar	Alapati Nagar	11kv	Mehdipatnam	08.25	09.30	01.05	EL,OL-Rph	Pin Insulator flash over at P & T Colony	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Surya Jothi	33kv	Jadcherla	11.58	14.15	02.17	O/L	Tree Branches touched to the 33KV Line line	Surya Jothi	-
1	MDK	Chegunta	Yeludurthy	33kv	Toopran	13.55	15.10	01.15		B/D Due to Jumper Cut	Yeludurthy	-
2		Manoharabad	shivampet	33kv	Toopran	09.35	10.30	00.55		B/D Due to Jumper Cut	shivampet	-
1	RR N	Bollaram	Bachupally	33kv	Kukatpally	09.52	14.35	04.43	BD	33kv Jumper cut at DRL	Bachupally	-