

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kothapally	33KV	Mahabubnagar	00.50	08.20	07.30	E/L	Pin Insulator Replaced Near Devargutta Thanda	Maddur	No
2		Maddur	Kankurthy	33KV	Mahabubnagar	05.50	08.40	02.50	E/L	Pin Insulator Replaced at Kankurthy(V)	Maddur	No
3		Maddur	Mogalmadka	33KV	Mahabubnagar	01.40	10.55	09.15	E/L	3No's Pin Insulator Replaced at Mogalmadka(V)	Maddur	No
4		Maddur	Pallerla	33KV	Mahabubnagar	01.45	09.30	07.45	E/L	Pin Insulator Replaced Near Pathamcherla Thanda	Maddur	No
5		Nagarkurnool	Ithole	33KV	Nagarkurnool	04.30	07.58	03.28	E/L	AB Switch Opened at Yetmathapur(V) & Alternate Supply arranged from 33KV Nagarkurnool at 7:58	Nagarkurnool	Alternate Supply arranged from 33KV Nagarkurnool at 7:58
6		Achampet	SLBC	33KV	Nagarkurnool	01.45	13.25	11.40	E/L	Alternate Supply From Inole at 13:25	Achampet	Alternate Supply From Inole at 13:25
7		Achampet	Kondanagula	33KV	Nagarkurnool	03.20	06.40	03.20	E/L	Alternate Supply From Lingal at 6:40Hrs	Achampet	Alternate Supply From Lingal at 6:40Hrs
1	NLG	Bhongiri	Bhongiri	33KV	Bhongiri	17.25	19.35	02.10		Jumper Cut	Bhongiri	-
2		Suryapet	Chandupatla	33KV	Suryapet	18.10	20.00	01.50		Heavy Gale and Wind Tree fallen the Line	Suryapet	-
3		Suryapet	Nimikal	33KV	Suryapet	17.10	20.40	03.30		Heavy Gale and Wind Jumper Cut	Suryapet	-
4		Suryapet	Penphadd	33KV	Suryapet	18.10	21.10	03.00		Heavy Gale and Wind Tree fallen the Line	Suryapet	-
5		Miryalaguda	V.K.Palem	33KV	Miryalaguda	14.50	21.00	06.10		Disk Failed	Miryalaguda	-
6		Bhongiri	B.P.Pally	33KV	Bhongiri	19.20	22.40	03.20		Heavy Gale and Wind Jumper Cut	Bhongiri	-
7		Kolanpaka	Sharajpet	33KV	Bhongiri	19.00	22.00	03.00		Line Falt	Kolanpaka	-
1	MDK	Siddipet	Thornal	33KV	Siddipet	18.50	21.05	02.15		B/D due to Insulator failure		-
2		Siddipet	Mittapally	33KV	Siddipet	18.50	21.00	02.10		B/D due to Insulator failure		-
1	RR N	132KV LGM Pet	33KV BE Pharma	33KV	Medchal	05.10	07.46	02.36	BD	BD Declared 33KV Pin Insulator failed & Replaced at Nektar Company		-
2		132KV LGM Pet	33KV LGM Pet	33KV	Medchal	05.10	06.20	01.10	BD	BD Declared 33KV Jumper & 2 Nos Pin Insulators failed & Replaced at LGM Pet Village ( Alternate Supply Arranged from 6:20 )		-
3		132KV Medchal	33KV Medchal-I	33KV	Medchal	05.10	07.25	02.15	BD	BD Declared PTR-III Pullout and Tree Fallen on 33KV Line at Forest Area,Medchal		-

## TSSPDCL - LMRC / Corporate office

Date: 06.06.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Dudyal	Hakeempet	11KV	Mahabubnagar	07.10	11.05	03.55		11KV Conductor cut at Erlapally (Vi)	-
2		Rawalpally	Angadiraichur	11KV	Mahabubnagar	08.00	12.00	04.00		11KV Jumper cut at Angadiraichur (vi)	-
3		Doulthabad	G F Wada	11KV	Mahabubnagar	05.30	11.00	05.30		11KV Conductor cut at G F Wada forest (Vi)	-
4		Doulthabad	Doulthabad rual	11KV	Mahabubnagar	03.40	10.30	06.50		11KV Tree fallen on conductor Yamiki (vi)	-
5		TELKAPALLY	GOUREDDY PALLY	11KV	Nagarkurnool	07.12	00.00	07.12		POLE DAMAGED	-
6		LINGAL	GINGUPALLY	11KV	Nagarkurnool	09.36	00.00	04.48		TREE TOUCHED 11KV LINE	-
7		LINGAL	CHENAMPALLY	11KV	Nagarkurnool	05.40	17.00	11.20		POLE DAMAGED HT/ LT	-
8		LINGAL	BALMOOR	11KV	Nagarkurnool	09.36	00.00	04.48		POLE DAMAGED & INSULATOR FAILED	-
1	NLG	K.M.Pally	Palvai	11KV	Devarakonda	14.30	17.30	03.00	EL	Insulator Failed	-
2		B.Chandupatla	Bheemlathanda	11KV	Suryapet	06.00	08.25	02.25	E/L	Jumper cut	-
3		Athmakur(S)	T.Penpahad	11KV	Suryapet	08.00	10.00	02.00	E/L	Insulator failed	-
4		Jalalpuram	Jalalpuram	11KV	Suryapet	12.10	14.50	02.40	E/L	Line Melt	-
5		Akkenapally	Akkenapally	11KV	Nalgonda	02.00	12.30	10.30	E/L	11 KV Line Insulator and Jumper cut at Akkenapally (V)	-
6		Annaparthi	Cherlapally AGL	11KV	Nalgonda	06.00	11.40	05.40	E/L	11 KV Jumper Cut Near by Smart City	-
7		Arjalabavi	Arjalabavi AGL	11KV	Nalgonda	08.40	14.00	05.20	E/L	11 KV Line Insulator Failed Near Village	-
8		Gudapaoor	Koratikal	11KV	Nalgonda	14.00	17.30	03.30	E/L	11 KV Jumper Cut Near Village	-
9		Palivela	Ipparthi	11KV	Nalgonda	02.00	09.30	07.30	E/L	HT/LT Lines Melt Near Kistapur Village SS-4	-
10		Anathram	Hanumapur	11KV	Bhongir	02.00	05.00	03.00	EL	11kv Insulator failed	-
11		B.P.Pally	Revanpally	11KV	Bhongir	07.00	12.00	05.00	EL	11KV Line snapped	-
12		Bhongir Town	Raigiri	11KV	Bhongir	11.00	15.30	04.30	EL	11Kv Diskfailed	-
1	MDK	Reddpally	Khajipet	11KV	Medak	09.20	10.30	01.10		B/D Due to Insulator failed	-
2		Yenigandla	Y Mandapur	11KV	Medak	06.00	10.30	04.30		B/D Due to Tree branches fallen on the line	-
1	RR S	Rajendranagar	University	11KV	Rajendranagar	04.22	05.55	01.33		11kv Insulator Failed at Bhavani colony Hanuman temple	-
2		NPA	Raghavendra colony	11KV	Rajendranagar	04.11	05.15	01.04		No Visible Fault Due to Rain	-
3		NPA	Shivarampally	11KV	Rajendranagar	04.16	05.10	00.54		No Visible Fault Due to Rain	-
4		NPA	Shastripuram	11KV	Rajendranagar	04.26	05.26	01.00		No Visible Fault Due to Rain	-
5		Gaganpahad	Gaganpahad	11KV	Rajendranagar	05.21	06.47	01.26		T/F Problem at Gaganpahad SS Opposite	-
1	RR N	Papi Reddy Nagar	RGK	11KV	Gachibowli	16.10	18.30	02.20	BD	Breaker Problem in Sub-Station	-
2		Madinaguda	JPN Nagar	11KV	Kukatpally	00.49	01.58	01.09	BD	Street light touched the 11 kv line at SMR Metro	-
3		Jeedimetla SS I	JETL	11KV	Kukatpally	03.40	07.50	04.10	BD	11kv AB Cable failure at SLN Kanta	-
4		Jeedimetla SS I	Phase V	11KV	Kukatpally	03.05	05.40	02.35	BD	11kv line's twist at Bush Chemical at Phase I	-
5		Jeedimetla SS I	Sudharshan Durgs	11KV	Kukatpally	03.05	08.00	04.55	BD	11kv post of insulator failure at Sai Industries	-
6		Jeedimetla SS I	NITCO	11KV	Kukatpally	03.10	05.30	02.20	BD	T/F Brass patti cut at Gas Company	-
7		Mayurinagar	Prashanthnagar	11KV	Kukatpally	06.10	07.40	01.30	BD	11kv AB Cable failure near II water tank at Prashanthnagar	-
8		Aliabad	Ravileela	11KV	Medchal	04.55	08.20	03.25	BD	Tree Branch fallen on the 11KV Line at St. John's High School Backside	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
9		ICICI	Eugia Pharma	11KV	Medchal	05.05	07.15	02.10	BD	11KV Pin Insulator failed at Eugia Pharma	-
10		Medchal	Rural Medchal	11KV	Medchal	17.35	19.15	01.40	BD	11KV Pin Insulator failed at Ganga Kaveri Seed Company	-
11		Athiwelly	SPIC	11KV	Medchal	19.00	21.05	02.05	BD	Tree Fallen on 11KV Line at Somaram Kaman(conductor Snapped)	-
1	RR E	P&T Colony	Medipally	11KV	HBG	01.50	03.10	01.20		Line petrolling done but no visale falt found due to Rain	-
2		NAGOLE	ADHARSH NAGAR	11KV	SAROOR NAGAR	17.23	18.40	01.17	OL	11KV LINE CUT AT NAGOLE	-
3		HAYATH NAGAR	KALVANCHA	11KV	SAROOR NAGAR	13.30	15.00	01.30	EL/OL	11KV LINE TOCHING AT KALVANCHA	-
4		Keesara	Ankireddypally	11KV	HBG	03.27	05.55	02.28		11KV line Pin insulator failed at Thata Hospital	-
5		RFC	UMAR KHAN GUDA	11KV	SAROORNAGAR	16.02	19.05	03.03	EL	11KV LINE AB SWITCH OPEN AT AEVTH COIAGE	-
6		PEDDA AMBERPET	PASUMAMALA	11KV	SAROORNAGAR	17.50	19.00	01.10	EL	CT AND BT FAIL AT PASUMAMALA	-
7		ABDULLAPETMET	MET TOWN	11KV	SAROORNAGAR	17.10	20.40	03.30	EL	11KV INSULATER FAIL AT ABDULLAPERMET	-
8		ABDULLAPETMET	SANGHI	11KV	SAROORNAGAR	17.10	18.30	01.20	EL	11KV INSULATER FAIL AT LASAKER GUDA	-
9		TARAMATHI PET	INDUSTRIAL	11KV	SAROORNAGAR	17.27	20.00	02.33	EL	THATI MATA FALLOW ON 11KV LINE AT BANDARAVIRALA	-
10		BANDARAVIRALA	BANDARAVIRALA	11KV	SAROORNAGAR	17.10	20.25	03.10	EL/OL	11KV POLE DAMGED AT BANDARAVIRALA	-
1	HYD N	E.S.I	Bapu Nagar	11KV	Erragadda	03.30	05.50	02.20	EL,OL-Bph	Faulty DTR at Bapu Nagar Basthi	-
2		N.I.M.S	Nagarjuna Hills	11KV	Banjarahills	03.35	05.55	02.20	EL	No Visible fault	-
3		K.I.M.S	S.P.Road	11KV	Sec-Bad	03.40	05.08	01.28	EL,OL-Bph	HT Jumper cut at Park Lane	-
4		M.L.A Colony	Lotus Pond	11KV	Banjarahills	03.40	05.30	01.50	All Indication	No Visible fault	-
5		Green Lands	Somajiguda	11KV	Erragadda	03.45	06.20	02.35	EL	No Visible fault	Arranged B/F on 11KV Topaz Building fdr
6		Yellareddyguda	Maruthi Nagar	11KV	Banjarahills	03.45	05.00	01.15	OL-R&Bph	Tree branches fallen on lines at S.K.D Nagar	-
7		K.I.M.S	Bapu Bagh	11KV	Sec-Bad	03.49	05.38	01.49	OL-Rph	HT Jumper cut at KIMS	-
8		Road No.13	Road No.1	11KV	Banjarahills	05.48	07.02	01.14	EL	RMU fault at Rd.No.1	-
1	HYD S	Asmangadh	Gowtham Nagar	11KV	Asmangadh	01.55	04.10	02.15	EL	Pin Insulator flash over at Cell One Apts	-
2		Moosaram Bagh	A.B.Colony	11KV	Asmangadh	04.00	05.00	01.00	OL-Bph	Tree branches fallen on lines at Sai Residency	-
3		Attapur	Puranapool	11KV	Charminar	05.05	07.00	01.55	EL	Cable fault at Andhra bank	-
1	HYD C	Indira Park	Kawadiguda	11KV	Saifabad	04.10	06.40	02.30	EL	Cable fault at Kavadiguda	Arranged B/F on 11KV Goshala fdr
2		Chilkaiguda	Musherabad	11KV	Saifabad	21.10	23.40	02.30	EL,OL	Lorry dash to RMU at Musherabad	Arranged B/F on 11KV Post Office feeder

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201		5		5		5			
5	RR(N)	77	404	3	11	3	11	3	11			
6	RR(E)	38	347		10		10		10			
7	Hyd	184	993		13		13		13			
	<b>Total</b>	<b>497</b>	<b>2892</b>	<b>3</b>	<b>39</b>	<b>3</b>	<b>39</b>	<b>3</b>	<b>39</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	108	969	7	8	7	8	7	8			
2	NLG	150	948	7	12	7	12	7	12			
3	MDK	87	828	2	2	2	2	2	2			
4	RR(S)	29	322									
5	RR(N)	8	48									
6	RR(E)	18	80									
	<b>Total</b>	<b>400</b>	<b>3195</b>	<b>16</b>	<b>22</b>	<b>16</b>	<b>22</b>	<b>16</b>	<b>22</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>897</b>	<b>6087</b>	<b>19</b>	<b>61</b>	<b>19</b>	<b>61</b>	<b>19</b>	<b>61</b>	<b>0</b>	<b>0</b>	