

TSSPDCL - LMRC / Corporate office

Date: 12.03.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Chegunta	Chegunta	33KV	Toopran	15.10	20.40	05.30		B/D Due to Disc failure and Jumper Cut	Chegunta	-
1	RR N	LGM Pet	Aliabad	33KV	Medchal	20.12	21.50	01.38	BD	Tree fallen on the 33KV Line at Rice Mill, Kolthur	LGM Pet	-
2		Medchal	Steel Mills	33KV	Medchal	08.30	09.50	01.20	BD	33KV Cable Endkit Failed at 132KV Medchal SS	Medchal	-

TSSPDCL - LMRC / Corporate office

Date: 12.03.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Jadcherla	11KV	Alwanpally	11.00	13.00	02.00		11KV Wire Cut Near Boyalakunta	-
1	NLG	Nuthankal	Yelkapally	11KV	Suryapet	03.30	07.25	03.55	EL	Insulator failed	-
2		Bondugula	Godumakunta	11KV	Bhongir	02.00	05.00	03.00	EL	11Kv Line snapped at Bondugula	-
1	RR N	ESCI	Lumbini Park	11KV	GCB	17.15	18.15	01.00	BD	Rods Fallen On The 11KV Line Near Quality Hotel, Back Side Lumbini Park	-
2		Shameerpet	Leo Meridian	11KV	Medchal	18.20	19.10	00.50	BD	11KV Pin Insulator failed at Ring Road	-
1	HYD S	Malakpet	Azampura	ST	VIII	16.30	17.45	01.15	All Indication	Star Cable fallen on Lines at Azampura Chaman	-

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	153									
2	NLG	18	406									
3	MDK	85	383									
4	RR(S)	38	237									
5	RR(N)	77	398	2	2	2	2	2	2			
6	RR(E)	38	347									
7	Hyd	169	966		1		1		1			
	Total	473	2890	2	3	2	3	2	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	104	894		1		1		1			
2	NLG	150	728		2		2		2			
3	MDK	94	826	1		1		1				
4	RR(S)	31	289									
5	RR(N)	8	49									
6	RR(E)	18	79									
	Total	405	2865	1	3	1	3	1	3	0	0	
	Grand Total	878	5755	3	6	3	6	3	6	0	0	