

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	38	209		1		1		1			
5	RR(N)	77	399		2		2		2			
6	RR(E)	38	347									
7	Hyd	183	982									
	<b>Total</b>	<b>494</b>	<b>2884</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	106	969	2	1	2	1	2	1			
2	NLG	150	948		2		2		2			
3	MDK	87	828									
4	RR(S)	27	316									
5	RR(N)	8	48									
6	RR(E)	18	80									
	<b>Total</b>	<b>396</b>	<b>3189</b>	<b>2</b>	<b>3</b>	<b>2</b>	<b>3</b>	<b>2</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>890</b>	<b>6073</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 29.03.2017

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Madelabanda	33KV	Gadwal	06.30	10.50	04.20		Tree Fallen on the Line at Madelabanda Canal	Madelabanda	-
2		Kothur	Ennar Steel	33KV	Jadcherla	18.35	20.55	02.20	O/L&E/L	Y Phase Jumper Cut & Disc Failure Near Thirupathi Company	Ennar Steel	-

## TSSPDCL - LMRC / Corporate office

Date: 29.03.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nagaram Gate	Nagaram	11KV	Mahabubnagar	07.30	10.00	02.30		11KV Conductor cut at Nagaram Forest	-
1	NLG	Cherukupally	Dindi rural	11KV	Devarakonda	13.00	16.00	03.00	E/L	11 KV Jumper cut	-
2		Bolepally	Jampally	11KV	Bhongiri	05.15	07.40	02.25	E/L	11KV Line snapped	-
1	RR S	Rajendranagar	Suleman Nagar	11KV	RJNR	17.41	18.56	01.15		No visible fault found	-
1	RR N	Gachibowli	Gopanpally	11KV	GCB	16.40	18.20	01.40	BD	11KV Line Insulator Failed At Natagenagar.	-
2		Kothaguda	Raghavendra Colony	11KV	GCB	12.30	13.10	00.40	BD	11KV AB Cable Failed at Golden Tulip Estate, Raghavendra colony	-