

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kothur	33KV	Mahabubnagar	01.10	07.10	06.00	E/L	visible fault due Heavy Rain & Wind	Kodangal	-
2		Wanaparthy	Wanaparthy	33KV	Wanaparthy	02.25	06.40	04.15	E/L	Tag on to Kothakota feeder	Wanaparthy	-
3		Wanaparthy	Buddaram	33KV	Wanaparthy	02.25	07.35	05.10	E/L	visible fault due Heavy Rain & Wind	Wanaparthy	-
4		Wanaparthy	Chinnamaroor	33KV	Wanaparthy	05.40	06.42	01.02	E/L	AB Switch open at Krishnapet	Wanaparthy	-
5		Singtom	Kollapur	33KV	Wanaparthy	02.49	05.37	02.48	E/L	visible fault due Heavy Rain & Wind	Singtom	-
6		leeza	Madelabanda	33KV	Gadwal	01.40	10.35	08.55	E/L	2 Poles setting work near Nagar Doddi,33KV Jumper cut near Kuntha reddy chrvu	leeza	-
7		Balanagar	Navadurg	33KV	Jadcherla	02.30	06.00	03.30	E/L&O/L	Jumper broken and replaced near Balanagar High way	Balanagar	-
8		Balanagar	Surya Jyothi	33KV	Jadcherla	03.50	09.30	05.40	E/L&O/L	Pin insulator replaced at Dilip Industrie	Balanagar	-
9		Mdjil	Velgomula	33KV	Jadcherla	05.30	08.01	02.31	E/L	Damaged pin insuator replaced near 33KV Velgomula SS	Mdjil	-
10		Mdjil	Vemula	33KV	Jadcherla	05.10	12.18	07.08	E/L	Damaged pin insuator replaced near by 132KV Midjil	Mdjil	-
11		Alwal	Ippalapally	33KV	Jadcherla	10.54	13.34	02.40	E/L	Disc Insulators changed near Vemulnarva Village	Alwal	-
12		Nagarkurnool	lthole	33KV	Nagarkurnool	03.40	10.28	06.48	E/L	No visible fault Due to Heavy Rain & Wind	Nagarkurnool	-
1	NLG	Bibinagar	Bollepally	33KV	Bhongir	22.10	09.00	10.10	E/L	Pin binding Failed , 33KV Diskfailed Near Hindustan Godown	Bibinagar	-
2		Ramannapet	Voligonda	33KV	Bhongir	04.15	12.10	06.55	E/L	Tree Fallen On Line Near Tekulasomaram	Ramannapet	-
3		Thungathurthy	Annaram	33KV	Suryapet	01.15	09.20	08.05	E/L	Insulator faild	Thungathurthy	-
4		Thungathurthy	Reddygudem	33KV	Suryapet	00.00	06.35	06.35	E/L	Tree branch fallen	Thungathurthy	-
5		S Gowraram	Akkinapally	33KV	Suryapet	03.30	08.00	04.30	E/L	Jumper open	S Gowraram	-
6		S Gowraram	Akaram	33KV	Suryapet	03.32	11.10	07.38	E/L	Line Melt	S Gowraram	-
7		S Gowraram	Arvapally	33KV	Suryapet	03.30	12.20	08.50	E/L	Line Melt	S Gowraram	-
8		Suryapet	Nemmikal	33KV	Suryapet	00.00	06.00	06.00	E/L	Jumper cut	Suryapet	-
9		Suryapet	Sudhakar PVC	33KV	Suryapet	00.00	08.50	08.50	E/L	Trip coil faild	Suryapet	-
10		Suryapet	GT Giri	33KV	Suryapet	00.00	09.20	09.20	E/L	Jumper cut	Suryapet	-
11		Mattampally	Huzurnagar	33KV	Huzurnagar	00.00	11.00	11.00	EL/OL	33 kv conductor snapped at Amararam village	Mattampally	-
12		Ramapuram	Ramapuram	33KV	Huzurnagar	03.10	13.15	11.05	EL/OL	33 kv conductor snapped at Ramapuram village	Ramapuram	-
13		Ramapuram	Thogarrai	33KV	Huzurnagar	09.45	10.30	00.45	EL/OL	33 kv line snapped at Thogarrai village	Ramapuram	-
14		K.M.Pally	Devarakonda	33KV	Devarakonda	02.30	05.00	02.30	E/L	11KV Jumper Cut	K.M.Pally	-
15		K.M.Pally	SLBC	33KV	Devarakonda	03.00	05.30	02.30	E/L	11KV Jumper Cut	K.M.Pally	-
16		Marriguda	Gattuppal	33KV	Devarakonda	06.00	09.15	03.15	E/L	insulator failure	Marriguda	-
17		Ramannapeta	Valigonda	33KV	Nalgonda	04.15	12.15	08.00	E/L	Insulator Failure	Ramannapeta	-
18		Ramannapeta	Yallanki	33KV	Nalgonda	02.45	11.15	08.30	E/L	Insulator Failure	Ramannapeta	-
19		Narketpally	Narketpally	33KV	Nalgonda	21.40	13.25	08.15	E/L	Insulator Failure	Narketpally	-
20		Marriguda	Gattupal	33KV	Nalgonda	06.00	12.00	06.00	E/L	Insulator Failure	Marriguda	-
21		Choutuppal	panthangi	33KV	Nalgonda	05.40	10.05	04.25	O/L	Insulator Failure	Choutuppal	-
22		Choutuppal	Narayanpur	33KV	Nalgonda	06:20	10.40	04.20	O/L	Insulator Failure	Choutuppal	-

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	SIDDIPET	Ragavapur	33KV	SIDDIPET	00.00	06.50	06.50		B/D due to Pin binding failed	SIDDIPET	-
2		Gummadidala	Jinnaram	33KV	Medak	23.50	06.10	06.20		B/D due to Insulator failed	Gummadidala	-
3		Gummadidala	AFA	33KV	Medak	22.40	11.40	13.00		B/D due to Insulator failed Dhoomadugu Village.	Gummadidala	-
4		Pedda Shankarampet	Regode	33KV	Jogipet	20.00	23.55	03.55		due to Under Breakdown	Pedda Shankarampet	-
5		Pedda Shankarampet	Pedda Shankarampet	33KV	Jogipet	20.00	23.55	03.55		due to Under Breakdown	Pedda Shankarampet	-
1	RR S	Dharmasagar	Shabad	33KV	VKB	00.15	06.50	06.35		33KV Insulator failed near Shabad(Vg)	Dharmasagar	-
2		Puttapahad	Doma	33KV	VKB	00.10	05.50	05.40		33KV Insulator failed at Bandenkacherla(Vg)	Puttapahad	-
3		Puttapahad	Mothukur	33KV	VKB	01.15	05.30	04.15		Tree branches fallen on 33KV line near Antharam(Vg)	Puttapahad	-
4		Pargi	Pargi	33KV	VKB	02.20	09.45	07.25		33KV Insulator failed at Nazeerabad Thanda	Pargi	-
5		220kv Shamshabad	33kv Shamshabad	33KV	RJNR	00.05	09.20	09.15		33kv Insulator failed at Thondupally railway track	220kv Shamshabad	-
6		220kv Shamshabad	33kv Shapur	33KV	RJNR	00.05	09.20	09.15		33kv Insulator failed at Thondupally railway track	220kv Shamshabad	-
1	RR N	Medchal	Bandamadaram	33KV	Medchal	22.35	03.45	05.10	BD	33KV Pin Insulator failed at Outer ringroad	Medchal	-
2		Medchal	Aliabad	33KV	Medchal	23.00	17.25	18.25	BD	33KV Disc Failed and Tree fallen on 33KV Line at Munirabad	Medchal	-
3		Medchal	Keshavaram	33KV	Medchal	22.53	08.51	09.58	BD	33KV Jumper Opened at Ganapur Village	Medchal	-
1	HYD C	132KV Chilalguda	Indira Park (Idle)	33KV	Saifabad	07.05	18.16	11.11	EL,OL	Disc Insulator flash over near Goshala	132KV Chilalguda	-

## TSSPDCL - LMRC / Corporate office

Date:  
10.05.2017

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kondapur	Kondapur	11KV	Mahabubnagar	04.30	09.10	04.40		11KV Line HT/LT at Kondapur (vi)	-
2		Kollur	Agiryal	11KV	Mahabubnagar	03.40	08.10	04.30		11KV Conductor cut at Agiryal (Vi)	-
3		Nawabpet	c) Lokirevu(karoor	11KV	Mahabubnagar	12.00	14.40	02.40		11KV Jumper cut at Lokirevu (vi)	-
4		Doultabad	b) Allapur	11KV	Mahabubnagar	06.30	10.30	04.00		11KV pole damage at Allapur (Vi)	-
5		Wanaparthy	Town-II	11KV	Wanaparthy	06.50	07.40	00.50		AB Switch Opened at Girakabavi.	-
6		Pangal	Annaram	11KV	Wanaparthy	08.00	10.30	02.30		11 KV Line Ph to Ph near Anjanagiri (V)	-
7		Kothapally	Kanchanpally	11KV	Jadcherla	08.00	11.00	03.00		DTR Failure at Limbya Tanda.	-
8		Urkonda	Mucherlapally	11KV	Jadcherla	06.30	10.30	04.00		11Kv Insulator Failed At Ramreddypally(vi).	-
9		Velgomla	Velgomla	11KV	Jadcherla	12.00	16.00	04.00		33Kv Insulator Failure At Ranipet Maisamma Temple Side.	-
10		Madharam	Rachalapally	11KV	Jadcherla	10.00	13.00	03.00		11Kv Wire Cut Near Ellikatta( Vi) Side.	-
11		NAGAR KURNOOL	YENDABETLA	11KV	Nagarkurnool	02.00	11.00	09.00		11 KV WIRE CUT NEAR VLG	-
12		TELKAPALLY	TELKAPALLY	11KV	Nagarkurnool	07.15	09.15	02.00		TREE TOUCH 11 KV LINE NEAR MRO OFFICE	-
13		ACHAMPET	ACHAMPET	11KV	Nagarkurnool	00.00	07.40	07.40		11 KV WIRE CUT NEAR VLG	-
14		PEDDUR	PEDDAPALLY	11KV	Nagarkurnool	06.10	13.00	06.50		11 KV JUMPER CUT NEAR PEDDUR VLG	-
15		BIJINAPALLY	BIJINAPALLY	11KV	Nagarkurnool	10.40	11.50	01.10		11 KV JUMPER CUT	-
16		KONDANAGULA	RAMJIPALLY	11KV	Nagarkurnool	03.30	09.30	06.00		INSULATOR FAILED NEAR VLG	-
17		LINGAL	BALMOOR	11KV	Nagarkurnool	02.15	10.00	07.45		P TO P & 11 KV LINE PRABULAM	-
18		KODAIR	MAHASAMUDRAM	11KV	Nagarkurnool	06.10	11.10	05.00		POLE DAMAGE	-
1		Alair	Ikkurthy	11KV	Bhongir	23.00	02.00	03.00	E/L	11KV Disk failed at Manthapuri	-
2		Antharam	Hanmpur	11KV	Bhongir	23.00	02.00	03.00	E/L	11KV Jumper snapped at Uhnava	-
3		N.G Bandal	Gandhamalla	11KV	Bhongir	23.00	03.00	06.00	E/L	2 Insulators failed Near Gandhamalla	-
4		Peddathand	Pallephad	11KV	Bhongir	02.00	06.00	04.00	E/L	Tree fallen On Line	-
5		B.p.pally	Muktapur	11KV	Bhongir	23.00	02.00	03.00	E/L	Pole Broken at Muktapur	-
6		Jublakpally	Vankamamidi	11KV	Bhongir	06.00	07.00	01.00	E/L	Tree fallen On Line	-
7		B.ramaram	Malyala	11KV	Bhongir	02.00	07.00	05.00	E/L	11KV Jumper snapped	-
8		B.ramaram	Hajipur	11KV	Bhongir	02.00	07.00	05.00	E/L	Pole Broken at Mailaram Village	-
9		Gundepuri	Gundepuri	11KV	Suryapet	00.25	08.00	07.35	E/L	Jumper cut	-
10		S V College	New Bus stand	11KV	Suryapet	04.00	09.00	05.00	E/L	line cut	-
11		Reddy gudem	Kothagudem	11KV	Suryapet	09.40	12.20	02.40	E/L	11KV line cut	-
12		Reddygudem	Maddirala	11KV	Suryapet	09.40	12.40	03.00	E/L	Pin insulator failed	-
13		Reddygudem	Kukkadam	11KV	Suryapet	09.50	12.00	02.10	E/L	Tree branch fallen on the line	-
14		Edloor	Prada	11KV	Suryapet	07.00	09.00	02.00	E/L	SS 3 Line cut	-
15		Edloor	Garlabagudem	11KV	Suryapet	07.00	08.30	01.30	E/L	SS-4 Jumper cut	-
16		Kodur	Loyapally	11KV	Suryapet	06.00	10.30	04.30	E/L	Jumper cut	-
17		Kodur	Kommala	11KV	Suryapet	00.35	06.00	05.25	E/L	Jumper cut	-
18		Palakeedu	Bothalapalem	11KV	Huzurnagar	03.00	09.00	06.00	E/L	1 ph DTR Failed at Bothalapalem village	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
19	NLG	Mkundapuram	Somaram	11KV	Huzurnagar	00.00	07.00	07.00	E/L	11 kv pin binding cutting at kasaram touched at jalagaramaihgudem village	-	
20		Mkundapuram	Dasaram	11KV	Huzurnagar	10.55	17.00	06.05	E/L	11 kv line snapped at dasaram village	-	
21		Amararam	Yatavakilla	11KV	Huzurnagar	00.00	08.45	08.45	E/L	HT/LT Line cutting at Yathavakilla village	-	
22		Mattampally	Choutapally	11KV	Huzurnagar	03.00	06.00	03.00	E/L	LT Line snapped at choutapally village	-	
23		Munagala	Turkagudem	11KV	Huzurnagar	00.30	08.00	07.30	E/L	11 kv jumper cut at kalakova village	-	
24		Repala	Kalakova	11KV	Huzurnagar	06.15	09.15	03.00	E/L	11 kv jumper cut at kalakova village	-	
25		Repala	Repala	11KV	Huzurnagar	06.00	10.30	04.30	E/L	11 kv jumper cut at Seetarampuram village	-	
26		Ananthagiri	Mogalaikota	11KV	Huzurnagar	00.05	08.55	09.00	E/L	11 kv line snapped at mogalaikota village	-	
27		Ananthagiri	Shantinagar	11KV	Huzurnagar	06.00	08.55	02.55	E/L	11 kv line snapped at Lakkavaram village	-	
28		Akupamula	Kodandarampuram	11KV	Huzurnagar	00.00	02.00	02.00	E/L	11 kv line pole damaged at Tellabelly	-	
29		Akupamula	Singaram	11KV	Huzurnagar	00.00	02.00	02.00	E/L	11 kv line pole damaged at Tellabelly	-	
30		Sirikonda	Lalthanda	11KV	Huzurnagar	10.00	11.00	01.00	E/L	11 kv line snapped at Lalthanda village	-	
31		Marriguda	Y.G.Pally	11KV	Devarakonda	06.30	08.10	01.40	E/L	11kv jumper cut	-	
32		Marriguda	Thamadapally	11KV	Devarakonda	06.30	11.00	04.30	E/L	11kv Transfer failure under SS-34 Near Bugga	-	
33		Pole Centre	Buddaram	11KV	Nalgonda	02.00	12.15	10.15	E/L	11KV Line Jumper Cut	-	
34		Narsingbatla	Kooturugudem	11KV	Nalgonda	06.05	13.00	06.55	E/L	11KV Line Jumper Cut	-	
35		Velugupally	lthavarigudem	11KV	Nalgonda	23.40	09.40	14.00	E/L	Pole Damaged at SS-10/4	-	
36		Pazzur	Kazi Ramaram	11KV	Nalgonda	08.40	09.40	01.00	E/L	11KV Line Jumper Cut at SS-9	-	
37		Pazzur	Pazzur	11KV	Nalgonda	03.00	09.20	06.20	E/L	AB Switch Problem at SS-2	-	
38		Madgulapally	Dacharam (Chervupally)	11KV	Nalgonda	12.00	07.00	05.00	E/L	11KV Line Jumper Cut	-	
39		Mamidala	Mamidala	11KV	Nalgonda	07.00	10.20	03.20	E/L	11KV Line Jumper Cut	-	
40		Choutuppal	Lingojigudem	11KV	Nalgonda	02.00	12.00	10.00	E/L	11KV Line Jumper Cut	-	
41		Choutuppal	Tangadepally	11KV	Nalgonda	02.00	12.00	10.00	E/L	Dick Failure	-	
42		D.Nagaram	D.Nagaram	11KV	Nalgonda	04.00	12.00	08.00	E/L	Insulator Failure	-	
43		Urumadla	Yelikatte	11KV	Nalgonda	03.40	07.20	03.40	E/L	HT/LT Line Melting at SS-6	-	
44		Yennaram	Suraram	11KV	Nalgonda	05.30	10.00	04.30	E/L	11KV Line Jumper Cut at SS-3	-	
45		Kanagal	Budamarlapally	11KV	Nalgonda	06.00	07.00	01.00	E/L	11KV Line Cut	-	
46		Thimmapuram	Kallepally	11KV	Miryalguda	11.15	18.30	07.15	E/L	Heavy Gale & Wind	-	
47		Nellikal	Chinthalapalem	11KV	Miryalguda	16.50	20.30	03.40	E/L	Heavy Gale & Wind	-	
1		MDK	Moosapet	Rusthumpet	11KV	Medak	10.00	12.00	02.00		B/D Due to Disk fail at Rusthumpet	-
2			Bujrampet	Bujrampet	11KV	Medak	01.00	07.00	06.00		B/D Due to Insulator fail	-
3	Gummadidala		Mambpur	11KV	Medak	01.00	08.00	08.00		B/D Due to Condcutor snapped at Mambapur village	-	
4	Nandigama		Pati	11KV	Sangareddy	07.30	09.00	01.30		B/D Due to AB switch burn at Pati Ghanpur Vg	-	
1		Uppar pally	Naidu colony	11KV	RJNR	23.35	08.22	08.47		B/F given on 11KB Bombay Colony	-	
2		Kattedan-I	Feeder-II	11KV	RJNR	23.05	01.16	02.11		No fault heavy gale and Rain	-	
3		Kattedan-I	Feeder-III	11KV	RJNR	01.10	06.30	05.20		No fault heavy gale and Rain	-	
4		Kattedan-I	Gangothri	11KV	RJNR	01.10	01.50	00.40		No fault heavy gale and Rain	-	
5		Kattedan-I	Gangothri	11KV	RJNR	03.00	04.00	01.00		No fault heavy gale and Rain	-	
6		Ibrahimbagh	Osmansagar	11KV	RJNR	23.10	06.29	07.19		Tree branches fallen on 11kv line at Taramathi	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
7	RR S	Ibrahimbagh	Military-II	11KV	RJNR	23.10	02.00	02.50		Tree branches fallen on 11KV line at Suncity	-
8		Ibrahimbagh	Military-I	11KV	RJNR	23.10	07.35	08.25		Tree branches fallen on 11KV line at Army Krishna Temple	-
9		Ibrahimbagh	Peddamangalaram	11KV	RJNR	23.10	01.27	02.17		Tree branches fallen on 11KV line at Hydarshakote G.P, More Market	-
10		Gandhamguda	Suncity	11KV	RJNR	01.10	02.35	01.25		Tree branches fallen on 11kv line at Raghuramnagar	-
11		Gandhamguda	Hydarshakote	11KV	RJNR	01.15	03.43	02.28		Tree branches fallen on 11kv line at 6yards	-
12		Gandhamguda	Kalimandir	11KV	RJNR	01.05	04.05	03.00		Tree branches fallen on 11kv line at Sanjaygandhinagar	-
13		APPA	Himayathsagar	11KV	RJNR	01.30	03.45	02.15		Flexy fallen on 11KV line at PBEL City	-
14		Gaganpahad	IDA Sathamrai	11KV	RJNR	01.28	02.20	00.52		11KV Disc failed at Patwari plastic	-
15		Gaganpahad	IDA Sathamrai	11KV	RJNR	04.10	06.34	02.24		Tree branches fallen 11kv line at Sathamrai	-
16		MD Pally	Pallecheruvu	11KV	RJNR	01.20	03.20	02.00		Tree branches fallen 11kv line at Pallecheruvu	-
17		MD Pally	Brundavancolony	11KV	RJNR	01.45	03.30	01.45		No fault heavy gale and Rain	-
18		Uppar pally	Upparpally(Upally)	11KV	RJNR	00.40	03.40	03.00		No fault heavy gale and Rain	-
19		Uppar pally	University	11KV	RJNR	00.40	04.10	03.30		Tree branches fallen on 11KV line at Bhavani colony	-
20		Kismathpur	Kismathpur	11KV	RJNR	03.40	05.45	02.05		11kv Pole damaged at SBI bank Kismathpur LAB Opened	-
21		Kismathpur	Rockchurch	11KV	RJNR	03.50	05.40	01.50		No fault heavy gale and Rain	-
22		Indirashivashakti	Indirashivashakti	11KV	RJNR	06.00	07.05	01.05		No fault heavy gale and Rain	-
23		Manikonda	Friendscolony	11KV	RJNR	03.16	05.28	02.12		Tree branches fallen on 11KV line at Latest school	-
24		NIRD	NIRD	11KV	RJNR	23.06	08.05	08.59		Tree branches fallen on 11KV Line at NIRD and SIRD T/F Pole Damaged	-
25		NIRD	Garayhounds	11KV	RJNR	23.07	05.50	06.43		Tree Branches fallen on 11KV line at ARR	-
26		Leninnagar	Badangpet	11KV	CPT	03.37	05.15	01.38		Due to heavy rain	-
27		Nandanavanam	Janardhan Reddy	11KV	CPT	00.00	01.25	01.25		Line petroling no fault	-
28		Nandanavanam	R N Reddy nagar	11KV	CPT	00.35	01.55	01.20		Line petroling no fault	-
29		Bairamalguda	Adhikarinagar	11KV	CPT	00.50	03.33	02.43		Line petroling no fault	-
30		Bairamalguda	Durga Nagar	11KV	CPT	00.12	04.18	04.06		Line petroling no fault	-
31		Bairamalguda	Janaki Enclave	11KV	CPT	00.22	02.30	02.08		Line petroling no fault	-
32		Champapet	Padmanagar	11KV	CPT	00.00	01.00	01.00		Heavy wind and gale	-
33		Almasguda	Rajeev Gruha Kalpa	11KV	CPT	02.00	04.10	02.10		11KV insulator failed at Rajeev Gruha Kalpa	-
34		Mallapur	Venkatapur	11KV	CPT	00.02	01.22	01.20		Heavy wind and gale	-
35		Mallapur	Shaheen nagar	11KV	CPT	03.06	04.45	01.39		Heavy wind and gale	-
36		Mallapur	Sulthanpur	11KV	CPT	03.47	04.10	00.23		Heavy wind and gale	-
37		Mallapur	Al jabri Colony	11KV	CPT	04.07	04.47	00.40		Heavy wind and gale	-
38		Thooroor	Ranganayakula gutta	11KV	CPT	00.15	03.10	02.55		Due to heavy rain	-
39		Turkayamjal	Turkayamjal	11KV	CPT	02.00	07.20	05.20		Due to heavy rain	-
40		Turkayamjal	Bramanpally	11KV	CPT	04.10	06.30	02.20		Due to heavy rain	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
41		Turkayamjal	ALL Feeders	11KV	CPT	00.00	02.00	02.00		Due to heavy rain	-
42		Vanasthalipuram	Vanasthalipuram	11KV	CPT	03.05	05.30	02.25		Due to heavy rain	-
43		Shaheb nagar	ALL Feeders	11KV	CPT	00.00	01.22	01.22		Due to heavy rain	-
44		Salkarpet	Pagidal	11KV	vkb	01.30	05.00	03.30		11kv line snapped near Pagidal.vg	-
45		Sidduloor	Pulusmamidi	11KV	vkb	00.00	08.00	08.00		11Kv Insulator failed at Danaram.vg	-
46		Madanpally	Madanpally	11KV	vkb	00.00	05.00	05.00		11Kv Insulator failed at Madanpally.vg	-
47		Devanurvelly	Kameta	11KV	vkb	02.30	05.30	03.00		11kv Line snapped at near by Gollapally.vg	-
48		Vikarabad	Anathagirri gutta	11KV	vkb	00.00	02.00	02.00		11Kv Insulator failed at RajivGurva kalpa	-
49		Chandanvelly	Chandanvelly	11KV	vkb	07.00	09.30	02.30		11kv Pole damjed at Chinna solipet.vg	-
50		Amangal	Vittaipally	11KV	shngr	02.00	04.00	02.00		Insulator failure	-
51		Mudwin	Charikonda	11KV	shngr	08.30	10.15	01.45		Conductor Damaged	-
52		Amangal	Polepally	11KV	shngr	02.15	05.00	02.45		Insulator failure	-
53		Amangal	Mangalpally	11KV	shngr	01.20	03.10	01.50		Conductor Damaged	-
54		Amangal	Akuthotapally	11KV	shngr	11.00	13.10	02.10		Conductor Damaged	-
55		Kadthal	Ravichedu 24 Hrs	11KV	shngr	03.20	05.10	01.50		Conductor Damaged	-
56		Mudwin	Ekwaipally	11KV	shngr	00.03	03.00	02.57		Conductor Damaged	-
57		Mudwin	Aukthotapally	11KV	shngr	01.05	03.01	01.56		Conductor Damaged	-
58		Talakondapally	Chandradhana	11KV	shngr	02.15	05.00	02.45		Insulator failure	-
59		Ravichedu	Ravichedu	11KV	shngr	12.10	15.40	03.30		Conductor Damaged	-
60		Chalampally	Salarpure	11KV	shngr	10.15	12.35	02.20		Conductor Damaged	-
61		Chalampally	Vepuguda	11KV	shngr	01.05	02.23	01.18		Conductor Damaged	-
62		Gattipalappally	Venkatraopet	11KV	shngr	00.22	02.44	02.22		Conductor Damaged	-
63		Veljal	Veljal	11KV	shngr	03.43	05.49	02.06		Insulator failure	-
64		Chandradhana	Veljal	11KV	shngr	15.05	16.22	01.17		Insulator failure	-
65		Madgul	China Madgul	11KV	shngr	09.50	11.29	01.39		Insulator failure	-
66		Madgul	Nallachervu	11KV	shngr	08.44	10.05	01.21		Conductor Damaged	-
67		Arkapally	Andhugula	11KV	shngr	01.06	05.00	03.54		Insulator failure	-
68		Appareddy pally	Jayram thanda	11KV	shngr	00.33	03.26	02.53		Insulator failure	-
69		33/11KV Chinna Elkicherla	11KV Chinna Elkicherla	11KV	shngr	03.30	07.20	03.50		Conductor dammaged	-
70		33/11KV Thimmapur	11KV Nandigama	11KV	shngr	07.05	08.27	01.22		Insulator failure	-
71		132/33KV Kothur	33KV Sangem	11KV	shngr	06.10	08.19	02.09		Insulator failure	-
72		132/33KV Alwal	33KV Ippalappally	11KV	shngr	05.40	07.55	02.15		Conductor Damaged	-
73		33/11KVSS Sangem	11KV Papireddyguda	11KV	shngr	04.53	07.47	02.54		Insulator failure	-
1		Papi Reddy Nagar	Dubey Colony	11KV	Gachibowli	03.00	07.00	04.00	BD	Tree branches fallen on the 11kv line,laxmi vihar brass patti cut & LT line snapped at adarsh nagar (Due to heavy wind and rain)	-
2		Mathrusri Nagar	Mathrusri Nagar	11KV	Gachibowli	03.35	05.30	01.55	BD	11kv Disc failed near geney school	-
3		IIIT	GPRA	11KV	Gachibowli	01.23	02.43	01.20	BD	Due To heavy rain & wind.	-
4		Gachibowli	Kalajyothi	11KV	Gachibowli	23.05	01.35	01.30	BD	Due To heavy rain & wind.	-
5		Gachibowli	Aparna	11KV	Gachibowli	23.10	03.35	04.45	BD	Due To heavy rain & wind.(Aparna load divided on Gopanpally feeder)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
6	RR N	Gachibowli	Gopanpally	11KV	Gachibowli	01.20	03.55	02.35	BD	Cable wire fallen on 11kv line near aparna(Due to heavy wind and rain)	-
7		SEZ	Siddique Nagar	11KV	Gachibowli	23.15	01.20	02.10	BD	Tree branches fallen on the 11kv line at Phoenix compond backside(Due to heavy wind and rain)	-
8		SEZ	New White Field	11KV	Gachibowli	01.25	02.45	01.20	BD	11kv Y phase jumper cut tuch to chanel at mahendra opposite(Due to heavy wind and rain)	-
9		Ayyappa Society	Hyundai	11KV	Gachibowli	23.04	02.04	03.00	BD	Flexi fallen on 11kv line near N-convention hall, Ayyappa society(Due to heavy wind and rain)	-
10		Ayyappa Society	Hyundai	11KV	Gachibowli	14.20	15.40	01.20	BD	11KV Pin Insulater Failed At Crusher, Ayyappa Society	-
11		ESCI	Care Hospital	11KV	Gachibowli	15.50	19.30	03.40	BD	11KV Care Hospital Breaker B Phase Limb Failed In Sub-Station (Back Feeding From Divya Sree Feeder)	-
12		Jeedimetla SS-I	Phase-I	11KV	Kukatpally	02.40	09.00	06.20	BD	HG fuse failed near Jecodia company ( Due to heavy rain)	-
13		Jeedimetla SS-I	Phase-II	11KV	Kukatpally	02.40	13.40	11.00	BD	Tree Branches fallen on the 11KV line and 11KV AB cable end kit failed. (Due to Heavy rain)	-
14		Jeedimetla SS-I	Nitco	11KV	Kukatpally	02.40	13.20	10.40	BD	11KV Jumper cut Dada Capacity Company.	-
15		Jeedimetla SS-I	CS Wires	11KV	Kukatpally	03.40	11.40	08.00	BD	Tree Branches fallen on the 11KV line . (Due to Heavy rain)	-
16		Jeedimetla SS-I	Sudarshan Drugs	11KV	Kukatpally	02.40	12.40	10.00	BD	Tree Branches fallen on the 11KV line & 11KV Jumper cut near S-Drugs Company . (Due to Heavy rain)	-
17		Jeedimetla SS-I	Maheshwari	11KV	Kukatpally	03.50	08.50	05.00	BD	Tree Branches fallen on the 11KV line near Eqied Company. (Due to Heavy rain)	-
18		Jeedimetla SS-II	Phase-IV	11KV	Kukatpally	01.15	09.55	08.40	BD	Tree Branches fallen on the 11KV line at near Karuna Enterprises.	-
19		Jeedimetla SS-II	Phase-V	11KV	Kukatpally	02.20	12.05	09.45	BD	11KV AB cable failed near Ken Clast Company & Tree branches fall on the 11KV line	-
20		Jeedimetla SS-III	Fox Sagar	11KV	Kukatpally	01.55	11.30	09.35	BD	11 KV Brass patti and Jumper cut at near Deccan Enterprises.	-
21		Suraram	Matrix	11KV	Kukatpally	03.10	09.05	05.55	BD	Due to heavy rain.	-
22		Bhahadurpally	Indiramma Colony	11KV	Kukatpally	03.05	04.30	01.25	BD	11KV AB cable blast at Ashramam Function Hall.	-
23		Jeedimetla SS - IV	AXIES	11KV	Kukatpally	23.55	10.10	10.15	BD	Tree Branches fallen on the 11KV line near AXIES Company. (Due to Heavy rain)	-
24		Jeedimetla SS - IV	Auto stand	11KV	Kukatpally	23.50	06.00	06.10	BD	UG Cable failure Back feeding from JDM SS I at 6 AM	-
25		Jeedimetla SS - IV	Tagoore	11KV	Kukatpally	02.30	05.00	02.30	BD	Tagoore feeder Jumper cut at SS yard (Due to Heavy rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
26		Chanda Nagar	Shankar Nagar	11KV	Kukatpally	02.30	05.00	02.30	BD	Big Flxi fall on the 11 kv line near Vindu Hotel at Chandanagar	-
27		Bachupally	Mallampet	11KV	Kukatpally	01.10	02.00	00.50	BD	11kv pin insulator, post of insulator failure near Mallampet Road	-
28		Kandlakoya	Kandlakoya	11KV	Medchal	02.40	04.00	01.20	BD	Tree fallen on the 11KV Line Near Outer ringroad	-
29		Medchal	Rural Medchal	11KV	Medchal	00.40	03.05	02.25	BD	Tree fallen on the 11KV Line at Kistapur Road	-
30		Kistapur	Kistapur	11KV	Medchal	06.15	07.50	01.35	BD	Tree fallen on the 11KV Line at Kistapur	-
31		Gowdavelly	Ayodhya	11KV	Medchal	04.00	06.45	02.45	BD	11KV Pin Insulator failed at Saketh Venture Backside, Near Gowdavelly Village	-
32		Athiwelly	Ravalkole Thanda	11KV	Medchal	07.20	11.20	04.00	BD	11KV Disk failed at Rekula Bhavi & Tree Branch fallen on the 11KV Line at Ravalkole Thanda	-
33		Medchal	Rural Medchal	11KV	Medchal	09.30	12.05	02.35	BD	Tree fallen on the 11KV Line at Check Post & Jyothi Nagar	-
34		Medchal	Navadurga	11KV	Medchal	10.40	12.10	01.30	BD	Tree fallen on the 11KV Line at Victory Thota	-
35		Shameerpet	Devarayamjal	11KV	Medchal	00.25	04.10	03.45	BD	11KV Conductor snapped at Bits bilani	-
36		Aliabad	HBL	11KV	Medchal	01.30	03.45	02.15	BD	Tree fallen on the 11KV Line at at Sumathi Company	-
37		Bommarajpet	Bommarajpet	11KV	Medchal	00.20	04.00	03.40	BD	11KV Pin Insulator failed at Bommaraj pet Cheruvu	-
38		Bommarajpet	Karkalamma	11KV	Medchal	07.50	09.50	02.00	BD	100KVA T/F Copper Patti Cut & Replaced at Jogul, Bommarajpet	-
39		Kompally	NCL	11KV	Medchal	01.00	02.43	01.43	BD	UG Cable opened at Shivashivani School	-
40		Kompally	Dholari Dhani	11KV	Medchal	01.10	03.06	01.56	BD	11KV Pin Insulatot failed at Saikrupa Apartment	-
41		Dulapally	IDA -II	11KV	Medchal	01.13	04.05	02.52	BD	11KV Pin Insulator failed at Glass company	-
42		Subash Nagar	Ramraj Nagar	11KV	Medchal	00.21	02.05	01.44	BD	11KV Pin Insulator failed at Green park	-
43		Subash Nagar	Jairam Nagar	11KV	Medchal	00.21	03.08	02.47	BD	Tree fallen on the 11KV Line at Srikrishna Nagar	-
44		Subash Nagar	Suchitra	11KV	Medchal	00.21	02.15	01.54	BD	Tree fallen on the 11KV Line at TNR Devalapars	-
45		Subash Nagar	Padma Nagar	11KV	Medchal	00.21	03.05	02.44	BD	63KVA New T/F Failure at Bank Colony	-
46		Subash Nagar	Pragatools Colony	11KV	Medchal	00.21	03.10	02.49	BD	Tree fallen on the 11KV Line Near Ramu Reddy House	-
47		UMCC	Mini Industry	11KV	Medchal	02.20	03.15	00.55	BD	Tree fallen on the 11KV Line at RM Nagar	-
1	RR E	Yapral	Yapral	11KV	SKP	09.25	10.25	01.00		Tree branches fallen on 11Kv line at Prathima Enclave (AE/OP/Yapral)	-
2		Moula-Ali	Spectra	11KV	SKP	12.58	14.45	01.47		11Kv Pin Insulatro failed at Kameneni Institute Idea Moula-Ali (AE/Moula-Ali)	-
3		Cherlapally-I	Surana	11KV	SKP	05.05	11.15	06.10		Lorry dashed on 11Kv Pole at Near Sub Station Gate (AE/OP/Cherlapally)	-
1		James Street	P.G.Road	11KV	V	00.25	02.55	02.30	All Indication	No Visible Fault	-



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD N	Road No.22	Road No.5	11KV	X	00.40	01.50	01.10	EL,OL-Rph	No Visible Fault	-
3		M.L.A Colony	K.B.R Park	11KV	X	01.10	02.40	01.30	All Indication	Faulty loads of 11KV Apollo fdr	-
4		M.L.A Colony	Kalinga	11KV	X	01.10	04.55	03.45	EL,OL-Rph	Big tree fallen on lines	-
5		M.L.A Colony	K.B.R Park	11KV	X	07.45	10.50	03.05	EL,OL-Rph	Tree branches fallen on lines	-
6		M.L.A Colony	Cancer Hospital	11KV	X	01.10	14.00	12.50	All Indication	Big tree fallen on lines at Noor Nagar	-
7		Borabanda	Peeli Darga	11KV	IV	00.10	03.30	03.20	EL	Tree branches fallen on lines	-
8		Borabanda	Swaraj Nagar	11KV	IV	00.10	03.45	03.35	EL	Tree branches fallen on lines	-
9		H.P.S	Post Office	11KV	IV	01.52	07.50	05.58	All Indication	Tree branches fallen on lines at Post Office	-
10		Madhapur	Ohri's	11KV	X	00.25	02.05	01.40	OL-Bph	No Visible Fault	-
11		Madhapur	Shilparamam	11KV	X	00.35	01.50	01.15	EL,OL-Rph	No Visible Fault	-
12		Chilkaiguda	Dandu Pentaiah	11KV	V	02.45	05.20	02.35	EL,OL-Rph	Twisted Lines at Saibaba Temple	-
13		Chilkaiguda	New Boiguda	11KV	V	03.40	05.40	02.00	EL	Star wire fallen on lines at Boiguda	-
14		Macha Bollaram	F.B.Nagar	11KV	VI	00.38	02.22	01.44	EL	No Visible Fault	-
15		K.I.M.S	D.V.Colony	11KV	V	00.50	02.36	01.46	OL-Rph	Faulty loads of 11KV Ranigunj fdr	-
16		M.L.A Colony	Shopping Complex	11KV	X	01.10	02.25	01.15	EL,OL-Rph	Tree branches on lines	-
17		Srinagar Colony	Udyog Nagar	11KV	X	00.32	11.02	10.30	EL,OL-Rph	Tree branches fallen on lines	-
18		Srinagar Colony	Kamala Nagar Colony	11KV	X	00.32	04.30	03.58	EL,OL-Bph	Tree branches fallen on lines	-
19		Srinagar Colony	Srinagar Colony	11KV	X	00.30	07.32	07.02	W/O Indication	Tree branches fallen on lines	-
20		Srinagar Colony	Yellareddyguda	11KV	X	00.30	07.20	06.50	EL,OL-Bph	Tree branches fallen on lines	-
21		Srinagar Colony	Satya Sai	11KV	X	00.32	09.35	09.03	EL,OL-Rph	Tree branches fallen on lines	-
22		Srinagar Colony	Nagarjuna Nagar	11KV	X	00.32	09.15	08.43	EL,OL-Bph	Tree branches fallen on lines	-
23		Srinagar Colony	Kamma Sangam	11KV	X	00.32	09.52	09.20	EL,OL-Bph	Tree branches fallen on lines	-
24		Lalaguda	Nagarjuna Nagar	11KV	V	00.38	01.50	01.12	EL,OL-Rph	Cloth fallen on lines at Anand Apts	-
25		Marredpally	Lalitha Nagar	11KV	V	00.45	03.25	02.40	W/O Indication	No Visible Fault	Arranged B/F on 11KV Railway Colony feeder
26		Yousufguda	Borabanda	11KV	IV	00.15	02.10	01.55	EL	No Visible Fault	-
27		H.P.S	Mayuri Marg	11KV	IV	01.54	03.55	02.01	EL	Tree branches fallen on lines at Mayuri Marg	-
28		H.P.S	Suryodaya Complex	11KV	IV	02.00	03.30	01.30	EL,OL-Bph	Tree branches fallen on lines	-
29		H.P.S	R.B.I Quarters	11KV	IV	02.05	05.30	03.25	EL,OL-Bph	Tree branches fallen on lines	-
30		Zamistanpur	Sanjeevapuram	11KV	V	01.25	02.55	01.30	EL,OL-Rph	No Visible Fault	-
31		Lodha	I.E	11KV	IV	05.42	10.54	05.12	EL	Tree branches fallen on lines	-
32		Lodha	Hanuman Temple	11KV	IV	08.44	10.51	02.07	EL	No Visible Fault	-
33		Lodha	Crown Casting	11KV	IV	09.10	11.02	01.52	OL-Rph	No Visible Fault	-
34		H.P.S	Varun Towers	11KV	IV	01.55	11.55	10.00	OL-R&Bph	Tree branches fallen on lines	-
35		Prashasan Nagar	Journalist Colony	11KV	X	04.12	09.55	05.43	EL	No Visible Fault	-
36		Road No.2	Shabdalaya	11KV	X	00.38	06.05	05.27	EL,OL-Rph	Tree branches fallen on lines	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
37		Road No.2	D.K.Basti	11KV	X	00.38	11.50	11.12	EL	Tree branches fallen on lines	-
38		Borabanda	Kalyan Nagar Park	11KV	IV	00.10	04.42	04.32	EL	Tree branches fallen on lines	-
39		H.P.S	Begumpet Nala	11KV	IV	01.55	12.30	10.35	EL	Tree branches fallen on lines	-
40		Greenlands	Hindu	11KV	IV	01.20	06.30	05.10	EL,OL-R&Bph	Tree fallen on lines at Panjagutta Area	-
41		Greenlands	Rajiv Gandhi	11KV	IV	01.20	02.30	01.10	EL,OL-R&Bph	Tree fallen on lines at Rajiv Gandhi Circle	-
42		Prashasan Nagar	Seri Culture	11KV	X	06.41	07.58	01.17	EL,OL	No Visible Fault	-
43		Sanjeevaiah Park	Police Line	11KV	V	01.18	03.05	01.47	OL-Rph	No Visible Fault	-
44		Marredpally	Addagutta	11KV	V	01.20	04.00	02.40	EL,OL-Yph	No Visible Fault	-
45		Road No.12	N.B.T Nagar	11KV	X	06.40	16.14	09.34	EL,OL	No Visible Fault	-
46		Maitrivanam	Ameerpet	11KV	IV	01.32	09.01	07.29	OL-Bph	Tree branches fallen on lines at Ameerpet	-
47		Maitrivanam	Anand Bagh	11KV	IV	01.32	06.43	05.11	EL,OL-Rph	Tree branches fallen on lines at Satyam Theater	-
48		Maitrivanam	Aditya Enclave	11KV	IV	01.32	06.54	05.22	EL	No Visible Fault	-
49		Maitrivanam	Maitrivanam	11KV	IV	01.32	08.40	07.08	EL	No Visible Fault	-
50		Kundan Bagh	Shanthi Shikara	11KV	IV	12.50	15.30	02.40	EL,OL	Snapped conductor at Ayyappa Temple	-
51		Begumpet	ESI Staff Quarters	11KV	IV	14.40	17.10	02.30	EL	No Visible Fault	-
52	Maitrivanam	Anand Bagh	11KV	IV	18.55	20.20	01.25	OL-Rph	No Visible Fault	-	
53	Kalyan Nagar	Vengalrao Nagar	11KV	X	21.28	23.29	02.01	EL	No Visible Fault	-	
54	Road No.13	Star Hospital	11KV	X	22.20	23.43	01.23	EL	Jumper cut at Road No. 10	-	
1	HYD S	E.N.T	Rang Mahal	11KV	IX	00.45	06.00	05.15	All Indication	RMU End Kit failed at S.B.I	-
2		E.N.T	C.B.I	11KV	IX	00.40	02.40	02.00	EL,OL-Rph	Tree branches fallen on lines at 94 Bus Stop	-
3		Vittalwadi	Narayanguda Water Works	11KV	IX	00.02	02.40	02.38	OL-R&Bph	Tree branches fallen on lines at Water Works	-
4		Falaknuma	Fathima Nagar	11KV	III	00.15	02.20	02.05	EL,OL-Rph	Conductor snapped at Urdhu School	-
5		Panjasha	Pancha Mohalla	11KV	III	00.01	01.06	01.05	EL,OL-Bph	No Visible Fault	-
6		Sulthan Bazar	Koti	11KV	IX	00.55	02.55	02.00	All Indication	No Visible Fault	-
7		Malakpet	Plant Protection	11KV	VIII	00.15	03.30	03.15	OL-R&Bph	No Visible Fault	-
8		Salarjung	Darulshifa	11KV	III	03.00	04.10	01.10	All Indication	Jumper cut at SS	-
9		Gunj	Palton	11KV	VIII	00.12	04.25	04.13	OL-Rph	Tree branches fallen on lines	-
10		Gunj	Gunj	11KV	VIII	00.23	05.40	05.17	EL	Jumper cut at Opp: Gunj	-
11		Gunj	Farhath Hospital	11KV	VIII	02.14	03.18	01.04	EL	No Visible Fault	-
12		Gunj	Race Course	11KV	VIII	04.10	05.45	01.35	EL	No Visible Fault	-
13		Miralam	Zoo Park	11KV	VIII	02.18	04.30	02.12	EL	No Visible Fault	-
14		Santosh Nagar	Chandra Huts	11KV	VIII	04.07	05.20	01.13	OL-Rph	No Visible Fault	-
15		Salarjung	Yakuthpura	11KV	VIII	04.15	05.30	01.15	EL,OL-Rph	No Visible Fault	-
16	Vittalwadi	Ram Koti	11KV	IX	00.55	03.25	02.30	EL	Cable fault	Arranged B/F on 11KV ENT feeder	
1		Nizam College	Galaxy Hotel	11KV	I	00.06	01.29	01.23	EL,OL-Rph	No Visible Fault	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD C	Nizam College	Shantha Bai Nursing Home	11KV	I	00.08	01.26	01.18	EL,OL-Rph	No Visible Fault	-
3		Golconda	Brindavan Colony	11KV	VII	00.00	01.20	01.20	EL,OL-Rph	No Visible Fault	-
4		Industrial Area	Vidya Nagar	11KV	II	01.00	02.25	01.25	EL,OL-Rph	No Visible Fault	-
5		Amberpet	6 Number	11KV	II	00.10	03.15	03.05	EL	No Visible Fault	-
6		Jawahar Nagar	Bank Of Baroda	11KV	I	02.40	04.20	01.40	OL-Rph	Jumper cut at Gandhi Nagar	-
7		Nampally	Pearl Regency	11KV	VII	05.01	07.46	02.45	EL,OL-Rph	Tree branches fallen on lines	-
8		Golnaka	Tulasi Nagar	11KV	II	00.06	02.58	02.52	OL	Tree branches fallen on lines	-
9		Mothi Mahal	M.D.Lines	11KV	VII	03.58	06.18	02.20	EL,OL	No Visible Fault	-
10		Hussain Sagar	V.R Colony	11KV	I	00.20	01.50	01.30	EL,OL-Rph	No Visible Fault	-
11		Hussain Sagar	Gunfoundry	11KV	I	01.40	05.00	03.20	EL,OL-Bph	No Visible Fault	-
12		Indira Park	Indian Bull	11KV	I	01.10	06.00	04.50	EL,OL-Bph	No Visible Fault	-
13		Indira Park	Gandhi Nagar	11KV	I	02.15	03.45	01.30	EL	No Visible Fault	-
14		Indira Park	Secretariate	11KV	I	03.00	04.20	01.20	EL,OL-Rph	No Visible Fault	-
15		Amberpet	Play Ground	11KV	II	00.50	02.45	01.55	EL	No Visible Fault	-
16		Narayanaguda	City Central Library	11KV	I	01.55	03.30	01.35	EL,OL-Rph	Tree branches fallen on lines at Anjaiah Bhavan	-
17		Mothi Mahal	Risala Bazar	11KV	VII	06.04	07.05	01.01	EL	No Visible Fault	-
18		Lake View	Satyam Computers	11KV	I	00.56	03.10	02.14	EL,OL	Tree branches fallen on lines at Somajiguda	-
19		Toli Chowki	Para Mount Colony	11KV	VII	10.30	12.00	01.30	OL-R&Bph	Banner fallen on lines at Gate No.2	-

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201	6	73	6	73	6	73			
5	RR(N)	77	404	3	47	3	47	3	47			
6	RR(E)	38	347		3		3		3			
7	Hyd	184	993	1	89	1	89	1	89			
	Total	497	2892	10	212	10	212	10	212	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	108	969	12	18	12	18	12	18			
2	NLG	150	948	22	47	22	47	22	47			
3	MDK	87	828	5	4	5	4	5	4			
4	RR(S)	29	322									
5	RR(N)	8	48									
6	RR(E)	18	80									
	Total	400	3195	39	69	39	69	39	69	0	0	
	Grand Total	897	6087	49	281	49	281	49	281	0	0	