



## TSSPDCL - LMRC / Corporate office

Date: 17.10.17

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Phanigiri	Malipuram	11KV	Suryapet	7:30	11:00	3:30	EL	11 KV Jumper cut	No
2		Kattangur	Bollepally	11KV	Nalgonda	06.00	09.00	03.00	EL	11 KV Jumper cut	No
3		Koppole K	Beemaram	11KV	Nalgonda	07.40	11.25	03.45	EL	11KV Disc failed	No
4		Kalmalacheruvu	Kalmalacheruvu	11KV	Huzurnagar	05.00	08.00	03.00	EL	11 KV Insulator failed	No
5		Repala	Narsimhulagudem	11KV	Huzurnagar	7:50	10:50	3:00	EL	11 KV Jumper cut	No
1	MDK	Dubbak	Lachapet	11KV	Siddipet	6:00	12:10	6:10		Tree branches fallen on the line	No
1	RR N	GP Pally	APIIC	11KV	Medchal	1:30	3:30	2:00		11KV Disc failed at APIIC Company Gate	No
2		Somasheela	Srinivasa Colony	11KV	Kukatpally	10.57	12.35	01.38	OL	11KV Line AB cable failed near Indu Tenchno school at Sapthagiri Colony	No
1	HYD N	Sanjeevaiah Park	Police Lines	11KV	Secunderabad	09.03	11.05	02.02	EL	UG Cable fault	Arranged B/F on 11KV Rani Bagh feeder
1	HYD S	Asmangadh	Jaya Nagar	11KV	Asmangadh	13.17	16.25	03.08	EL,OL-Bph	Faulty loads of 11KV LIC feeder	No

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		2		2		2			
6	RR(E)	38	360									
7	Hyd	186	1014		2		2		2			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969									
2	NLG	150	948		5		5		5			
3	MDK	87	828		1		1		1			
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	