

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	48	158									
2	NLG	18	406									
3	MDK	92	383									
4	RR(S)	40	201									
5	RR(N)	82	407		1		1		1			
6	RR(E)	38	360		2		2		2			
7	Hyd	186	1014		1		1		1			
	<b>Total</b>	<b>504</b>	<b>2929</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	110	969		1		1		1			
2	NLG	150	948									
3	MDK	87	828									
4	RR(S)	31	338									
5	RR(N)	8	48									
6	RR(E)	18	89									
	<b>Total</b>	<b>404</b>	<b>3220</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>908</b>	<b>6149</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 12.01.18

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	K.C.Road	Chindarpally	11KV	Mahabubnagar	12.14	16.20	04.06		11KV Conductor cut at VenkatapurThanda (V)	No
1	RR N	Madinaguda	Swaranapuri colony	11KV	Kukatpally	5:50	7:30	1:40	EL	T/F 2Nos Brasspatti cut at H M T Maqtha	No
1	RR E	Pocharam	Jodimetla	11KV	Keesara	17:30	18:30	1:00		11KV Jumper cut at Chouderiguda	No
2		Injapur	CRPF	11KV	Ibrahimpattam	13.24	14.16	00.52	EL/OL	Bird fallen on the 11KV line	No
1	HYD S	Attapur	Shareef Nagar	11KV	Charminar	05.18	07.23	02.05	EL,OL-R&Bph	2No. DTR's fault at Baba Nagar	No

